PLAN
SURVEYED
PLOTTED
GRADES CHECKED
BM. NOTED
NOTE BOOK
NO.
ALIGNMENT CHECKED
P.O.T. CHECKED
PLAN FILE NAME
BY
DATE

PROFILE
SURVEYED
PLOTTED
GRADES CHECKED
BM. NOTED
NOTE BOOK
NO.
STRUCTURE NOTATIONS CHKD
BY
DATE

N

GRAPHIC SCALE IN FEET 20' 0' 20'

SANDY STREET

MAUVAISTERRE STREET

MORGAN STREET

MORGAN STREET

PROPOSED WATERMAIN LINESTOP, 10", 1-EACH
PROPOSED WATERMAIN CAP, 10", 1-EACH
PROPOSED 10"x10"x6" TEE, 1-EACH
PROPOSED FIRE HYDRANT COMPLETE, 1-EACH
PROPOSED WATERMAIN 6", 25 LF
PROPOSED WATERMAIN 10", 265 LF
PROPOSED WATER VALVE 10", 1-EACH (W/VB)
EXISTING 10" WATERMAIN TO REMAIN IN SERVICE
SURVEY @ MORGAN STREET
PROPOSED 10"x10"x6" TEE, 1-EACH
PROPOSED WATER VALVE 6", 1-EACH (W/VB)
PROPOSED WATERMAIN 6", 10 LF
PROPOSED WATERMAIN LINESTOP, 6", 1-EACH
STA 31+85-15' RT= STA 51+85-15 LT
EXISTING 6" WATERMAIN TO REMAIN IN SERVICE
PROPOSED 10"x10"x10" TEE, 1-EACH
PROPOSED WATER VALVE 10", 1-EACH (W/VB)
PROPOSED WATERMAIN 10", 121 LF
PROPOSED WATERMAIN LINESTOP, 10", 1-EACH
PROPOSED WATERMAIN CAP, 10", 1-EACH
PROPOSED 10"x6" REDUCER, 1-EACH
PROPOSED WATER VALVE 6", 1-EACH (W/VB)
PROPOSED FIRE HYDRANT COMPLETE, 1-EACH
PROPOSED WATERMAIN 6", 25 LF
PROPOSED WATERMAIN 6", 226 LF
PROPOSED WATERMAIN 6", 18 LF
PROPOSED 10"x10"x10" TEE, 1-EACH STA 34+50-15' RT
PROPOSED 6"x6"x6" TEE, 1-EACH
PROPOSED 6"x 6"x 6" TEE, 1-EACH
PROPOSED 6"x6"x6" TEE, 1-EACH
PROPOSED WATER VALVE 6", 1-EACH (W/VB)
PROPOSED WATERMAIN 6", 10 LF
PROPOSED WATERMAIN LINESTOP, 6", 1-EACH
PROPOSED WATERMAIN LINESTOP, 10", 1-EACH
PROPOSED WATERMAIN CAP, 6", 1-EACH
PROPOSED 6"-90° BEND STA 36+76-15' RT STA 61+85-15' RT
EXISTING 6" WATERMAIN TO REMAIN IN SERVICE

GENERAL NOTES

1. ALL EXISTING BUFFALO/ VALVE BOXES ON EXISTING WATER SERVICES OR WATERMAIN TO BE ABANDONED, WILL BE REMOVED. COST TO BE INCLUDED IN "ABANDON EXISTING WATERMAIN" PAY ITEM.

0.89%

EXISTING PROFILE GRADE LINE

PROPOSED PROFILE GRADE LINE ℄ MORGAN STREET

MINIMUM 4'-6" BURY OVER THE TOP OF PIPE (TYP)

2'± CLEARANCE BETWEEN WATERMAIN AND 15" STORM SEWER

PROPOSED WATERMAIN 10", 265 LF

PROPOSED WATERMAIN 6", 226 LF

2'± CLEARANCE BETWEEN WATERMAIN AND 12" STORM SEWER

620 618 616 614 612 610 608 606 604

615.10 614.66 615.36 615.25 614.71 615.06 614.38 614.62 613.94 614.18 613.12 613.73 613.15 613.29 613.01 612.85 612.58 612.63 611.78 611.44

31+50 32+00 32+50 +79.20 33+00 33+50 34+00 34+50 35+00 35+50 +80.44 36+00 36+50 +80.44 37+00

FILE NAME = v:\2557\MORGANWMPP1.dgn	USER NAME = jwhite	DESIGNED - JRB	REVISED -
		DRAWN - JMO	REVISED -
	PLOT SCALE = 20.0000 ' / IN.	CHECKED - JRB	REVISED -
	PLOT DATE = 9/25/2009	DATE - 09/25/09	REVISED -

STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

CITY OF JACKSONVILLE DOWNTOWN PLAZA STREETS RECONSTRUCTION
MORGAN STREET WATERMAIN SHEET

SCALE: 1" = 20' | SHEET NO. OF SHEETS | STA. 31+70.00 TO STA. 36+91.04

F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
N/A	05-00121-00-PV	MORGAN	74	30
		CONTRACT NO. 93504		
FED. ROAD DIST. NO. 6	ILLINOIS	FED. AID PROJECT		