



NOTES:
 1) SEWERS THAT ARE TO BE ABANDONED SHALL HAVE EACH END PLUGGED PRIOR TO FILLING THE STRUCTURE. THE SEWER SHALL BE PLUGGED WITH A 2' LONG CONCRETE BULKHEAD. THIS WORK SHALL BE CONSIDERED INCIDENTAL TO FILLING THE STRUCTURE AND WILL NOT BE PAID FOR SEPARATELY.

LEGEND		EXISTING	PROPOSED
(A)	STRUCTURE TO BE ADJUSTED	(X)	VALVE VAULT
(B)	STRUCTURE TO BE CLEANED	(O)	MANHOLE
(C)	FILLING EXISTING STRUCTURE	(□)	CATCH BASIN
(D)	STRUCTURE TO BE ADJUSTED WITH NEW FRAME & LID	(○)	INLET
(E)	STRUCTURE TO BE RECONSTRUCTED WITH NEW FRAME & LID	(●)	FIRE HYDRANT
(F)	STRUCTURE TO BE REMOVED	(○)	FIRE HYDRANT
(G)	FRAME & LID TO BE ADJUSTED SPECIAL	(○)	FIRE HYDRANT
(H)	SEWER TO BE ABANDONED	(○)	FIRE HYDRANT
(I)	STRUCTURE TO BE ADJUSTED SPECIAL	(○)	FIRE HYDRANT
(J)	STRUCTURE TO BE RECONSTRUCTED SPECIAL	(○)	FIRE HYDRANT
(K)	STRUCTURE TO BE ABANDONED	(○)	FIRE HYDRANT
(L)	FILLING EXISTING STRUCTURE SPECIAL	(○)	FIRE HYDRANT
(M)	STRUCTURE TO BE RECONSTRUCTED WITH NEW FRAME & LID	(○)	FIRE HYDRANT
(N)	STRUCTURE TO BE ADJUSTED WITH NEW FRAME & LID	(○)	FIRE HYDRANT
(O)	STRUCTURE TO BE REMOVED	(○)	FIRE HYDRANT
(P)	FRAME & LID TO BE ADJUSTED SPECIAL	(○)	FIRE HYDRANT
(Q)	SEWER TO BE ABANDONED	(○)	FIRE HYDRANT

STRUCT. NO.	STATION	OFFSET	STRUCTURE TYPE	RIM	INVERT								
					NORTH	N.E.	SOUTH	S.E.	EAST	S.W.	WEST	N.W.	
S-11	205+06	2' LT	MAN SAN 4 DIA T1F CL REMOV MANHOLES	667.22	-	-	657.97	-	656.74	-	656.74	-	-
S-12	205+90	11.5' LT	CB TA 4 DIA T23F&G	667.32	-	-	-	664.32	-	-	-	-	-
S-13	205+90	7' LT	MAN TA 5 DIA T1F CL	667.41	-	-	-	-	655.09	-	655.19	664.22	-
S-14	206+77	2' LT	MAN SAN 4 DIA T1F CL REMOV MANHOLES	667.82	-	-	656.37	-	656.05	-	656.05	-	-
S-15	206+92	17.5' RT	CB TA 4 DIA T23F&G	667.08	664.08	-	-	-	-	-	-	-	-
S-16	209+26	C.L.	MAN SAN 4 DIA T1F CL REMOV MANHOLES	666.63	-	-	-	-	655.21	-	655.21	-	-
S-18	206+85	12' LT	MAN RECON NEW T1F CL	667.66	-	-	652.90	663.78	652.90	-	653.96	-	-

NO.	LENGTH (FOOT)	MATERIAL	TYPE	DIA. (IN)	SLOPE %	TBF (CU. YD.)
P-11	129	SS RG CLA	3	18	1.30	239
P-12	4	STORM S PVC SDR26	1	12	2.50	1
P-13	95	SS RG CLA	3	18	1.30	207
P-14	30	STORM S PVC SDR26	1	12	1.00	9

STRUCT. NO.	STATION	OFFSET	STRUCTURE TYPE	RIM	NOTES
W-5	206+50	33' RT	FIRE HYDRANTS TO BE MVD	-	-

SCALES:
 1" = 20' HOR
 1" = 5' VER

