



**NOTES:**  
 1) SEWERS THAT ARE TO BE ABANDONED SHALL HAVE EACH END PLUGGED PRIOR TO FILLING THE STRUCTURE. THE SEWER SHALL BE PLUGGED WITH A 2' LONG CONCRETE BULKHEAD. THIS WORK SHALL BE CONSIDERED INCIDENTAL TO FILLING THE STRUCTURE AND WILL NOT BE PAID FOR SEPARATELY.

LEGEND		EXISTING	PROPOSED
(A) STRUCTURE TO BE ADJUSTED	(ASB) STRUCTURE TO BE ADJUSTED SPECIAL	(X) VALVE VAULT	(X) VALVE VAULT
(C) STRUCTURE TO BE CLEANED	(RSP) STRUCTURE TO BE RECONSTRUCTED SPECIAL	(O) MANHOLE	(O) MANHOLE
(F) FILLING EXISTING STRUCTURE	(AB) STRUCTURE TO BE ABANDONED	(C) CATCH BASIN	(C) CATCH BASIN
(A) STRUCTURE TO BE ADJUSTED WITH NEW FRAME & LID	(FSS) FILLING EXISTING STRUCTURE SPECIAL	(I) INLET	(I) INLET
(M) STRUCTURE TO BE RECONSTRUCTED WITH NEW FRAME & LID	(R) STRUCTURE TO BE RECONSTRUCTED WITH NEW FRAME & LID	(FH) FIRE HYDRANT	(FH) FIRE HYDRANT
(REM) STRUCTURE TO BE REMOVED	(FM) FILLING EXISTING STRUCTURE AND MAINTAIN FLOW		
(A) FRAME & LID TO BE ADJUSTED SPECIAL			
(//) SEWER TO BE ABANDONED			

STRUCT. NO.	STATION	OFFSET	STRUCTURE TYPE	RIM	COORDINATES							
					NORTH	N.E.	SOUTH	S.E.	EAST	S.W.	WEST	N.W.
S-3	9+47	11.8' LT	CB TA 4 DIA T23F&G	667.11	-	-	-	-	664.11	-	-	-
S-47	6+85	12' RT	INLETS TA T3F&G	665.60	662.43	-	-	-	-	-	-	-
S-48	6+95	12' RT	CB TA 4 DIA T3F&G	665.50	-	-	662.33	-	-	-	662.23	-
S-49	6+85	12' LT	INLETS TA T3F&G	665.60	662.48	-	-	-	-	-	-	-
S-50	6+95	12' LT	CB TA 4 DIA T3F&G	665.40	-	-	662.38	-	662.28	-	-	-
S-51	6+95	4' RT	MAN TA 5 DIA T1F CL	665.92	662.03	-	-	-	662.13	-	662.13	-
S-52	7+50	4' RT	MAN TA 4 DIA T1F CL	666.16	661.38	-	661.48	-	-	-	-	-
S-53	8+00	6' LT	MAN TA 4 DIA T1F CL	666.41	660.78	-	660.88	-	-	-	-	-
S-54	8+83	12' LT	EXIST CB	666.56	-	-	-	-	663.01	-	-	-
S-55	8+90	4' RT	MAN TA 4 DIA T1F CL	667.15	659.88	-	659.98	-	-	-	662.86	-
S-56	9+47	4' RT	MAN TA 4 DIA T1F CL	667.28	659.23	-	659.33	-	-	-	663.96	-

NO.	LENGTH (FOOT)	MATERIAL	TYPE	DIA. (IN)	SLOPE %	TBF (CU. YD.)
P-3	15	STORM S PVC SDR26	1	12	1.00	4
P-4	63	SS RG CLA	2	18	1.00	87
P-32	10	STORM S PVC SDR26	1	12	1.00	3
P-33	8	STORM S PVC SDR26	1	12	1.25	3
P-34	10	STORM S PVC SDR26	1	12	1.00	3
P-35	15	STORM S PVC SDR26	1	12	1.00	5
P-36	55	SS RG CLA	2	18	1.00	22
P-37	50	SS (PVC) SDR 26 (C900)	1	18	1.00	38
P-38	90	SS (PVC) SDR 26 (C900)	1	18	1.00	88
P-39	15	STORM S PVC SDR26	1	12	1.00	5
P-40	55	SS RG CLA	2	18	1.00	66

SCALES:  
 1" = 20' HOR  
 1" = 5' VER

