



EXISTING IDOT LIGHTING CONTROLLER "C"
 240/480V, 1PH, 3W TO REMAIN,
 SEE NOTE 1

NOTES:

- CONTRACTOR SHALL MODIFY THE EXISTING CONTROLLER BY REPLACING EXISTING MAIN BREAKERS (2) 150A/2P WITH (2) 175A/2P. BOLT ON TYPE NEW BREAKERS MUST BE RATED FOR 22000 RMS SYMMETRICAL AMPS AT 480V AND LABELED AS SERVICE ENTRANCE.



Globetrotters*
 Engineering Corporation
 ENGINEERS ARCHITECTS
 300 South Wacker Drive
 Chicago, Illinois 60606

USER NAME = mikosir
PLOT SCALE = 1/8"=1'
PLOT DATE = 19-OCT-2012

DESIGNED <i>CD</i>	REVISED -
DRAWN <i>RL</i>	REVISED -
CHECKED <i>CD</i>	REVISED -
DATE <i>10/19/12</i>	REVISED -

**STATE OF ILLINOIS
 DEPARTMENT OF TRANSPORTATION**

**LIGHTING REMOVAL PLAN, PRE STAGE,
 CONTROLLER C MODIFICATION**

SCALE: 1" = 100' SHEET NO. OF SHEETS STA. TO STA.

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
330	0105 WRS&HB	COOK	605	293
CONTRACT NO. 60G37				
ILLINOIS FED. AID PROJECT				