



- NOTES:**
- REFER TO DRAWING E1 FOR GENERAL NOTES, LEGEND AND ABBREVIATIONS.
 - REFER TO DRAWINGS E15 THRU E20 FOR DETAILS.
 - REFER TO DRAWING E21 FOR LIGHT POLE SCHEDULE AND DRAWING E22 FOR LIGHTING SINGLE LINE DIAGRAM.
 - CONTRACTOR SHALL PROVIDE TEMPORARY LIGHTING PRIOR TO DEMOLITION WORK. PROVIDE TEMPORARY POLE AND OVERHEAD TEMPORARY CIRCUIT. CONNECT TO EXISTING LIGHTING CIRCUIT IN AREA. COORDINATE EXACT TEMPORARY POLE QUANTITY AND LOCATION WITH VILLAGE OF ARLINGTON HEIGHTS.
 - LOCATION OF EXISTING CONDUIT AND CABLE IS APPROXIMATE. FIELD VERIFY REQUIRED FOR EXACT LOCATION OF CONDUIT ROUTING.
 - CONTRACTOR SHALL MODIFY EXISTING CONTROLLER FOR TEMP. LIGHTING. REFER TO DETAIL NO. 2 ON DRAWING E15 FOR EXISTING CONTROLLER INFORMATION. COORDINATE TEMPORARY CONNECTION WITH VILLAGE OF ARLINGTON HEIGHTS.
 - CONTRACTOR SHALL MOUNT TEMPORARY PHOTOCELL ON TEMP WOOD POLE AND ROUTE TEMP CONTROL CABLES THROUGH SAME CONDUIT AS LIGHTING CIRCUIT BACK TO EXISTING LIGHTING CONTROLLER. PHOTOCELL SHALL BE POSITIONED SO NO NEARBY AMBIENT LIGHT INTERFERES WITH ITS FUNCTION.
 - POLE SETBACK IS MEASURED FROM ROADWAY CENTERLINE TO CENTER OF POLE.



REVISIONS	
NAME	DATE

VILLAGE OF ARLINGTON HEIGHTS

TEMP. LIGHTING PLAN-3

U.S. ROUTE 14

STA. 557+00 TO STA. 562+00

DATE: 08/17/2012
DESIGNED BY: EE
TECHNICIAN: EE
CHECKED BY: DEM

0 HORIZ.
20 SCALE IN FEET 20 VERT.