



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

January 17, 2006

SUBJECT: FAI Route 80/94
Section 2626.2 R-2
Cook County
Contract No. 62114
Item No. 4P, January 20, 2006 Letting
Addendum C

NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

1. Revised page 48 of the Special Provisions.

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

Michael L. Hine
Engineer of Design
and Environment

A handwritten signature in cursive script, reading "Ted B. Walschleger" followed by a small "P.E." to the right.

By: Ted B. Walschleger, P. E.
Engineer of Project Management

cc: Diane O'Keefe, Region 1, District 1; N. R. Stoner; Roger Driskell; R. E. Anderson; Estimates; Design & Environment File

TBW:TK:jc

Stabilized Sub Base: This work shall be performed according to the special provision, "Superpave Bituminous Concrete Mixtures". The mixture used shall be the Superpave IL-19.0, N50, 3.0% voids.

Pavement and Shoulders: Add the following to Articles 420.03, 421.03, and 483.03:

"The Contractor shall submit to the Engineer, for approval before paving, the proposed internal type vibrator spacing for the paver. The Contractor shall also provide the proposed vibrator operating frequencies for a paving speed greater than or equal to 3 ft./min. and a paving speed less than 3 ft/min."

Add the following to Article 421.05:

"When the surface temperature, as measured on the surface with a device as approved by the Engineer, of the Stabilized Sub-base is 115°F or greater the Contractor shall spray the Stabilized Sub-base with a water mist with equipment that meets the approval of the Engineer. The Stabilized Sub-base shall be cooled below 115°F prior to paving on top. The water spray shall not produce excessive water runoff or leave puddles on the Stabilized Sub-base at the time of paving. All cooling shall be completed a minimum of 10 minutes prior to paving. The surface temperature shall be monitored during the paving operation to determine if the Stabilized Sub-base requires re-spraying.

The water used shall meet the requirements of Section 1002."

Portland Cement Concrete:" Revise Article 1020.02 (d) to read:

"(d) Coarse Aggregate (Note 1)1004.01 – 1004.02"

Add the following to Article 1020.02:

"Note 1. For pavement, median, curb, gutter, combination curb and gutter and concrete barrier, the freeze-thaw rating expansion limit for the coarse aggregate shall be a maximum of 0.040 percent according to Illinois Modified AASHTO T 161, Procedure B."

Revise the curing table of Article 1020.13 as follows:

"The curing period for pavement, median, curb, gutter and combination curb and gutter shall be a minimum of 7 days."

Revise the first sentence of the second paragraph of Article 1020.13 (a)(4) to read:

"Membrane curing shall be completed within ten minutes after tining."

Revised 01/17/2006