


LEGEND:

- EXISTING UNIT DUCT
- PROPOSED TEMPORARY AERIAL CABLE
- ⊗ EXISTING LIGHT POLE TO REMAIN UNLESS NOTED OTHERWISE
- ⊠ EXISTING LIGHTING CONTROLLER
- PROPOSED TEMPORARY BREAKAWAY POLE 45 FT M.H. TENON MOUNT WITH 250W HPS MM FIXTURE
- 2 UNIT DUCT, 600V, 2-1C NO.2, 1/C NO.2 GROUND, (XLP-TYPE USE), 1/4" DIA. POLYETHYLENE
- 4 AERIAL CABLE, 2-1/C NO. 2 WITH MESSENGER WIRE

NOTE:
CONTROLLER 2 UPGRADED TO 100A TO ACCOMMODATE WISCONSIN CROSSOVER TEMPORARY LIGHTING.



USER NAME = .USERNAME.	DESIGNED - BLM	REVISED -
PLOT SCALE = 50.0000' / IN.	DRAWN - JPW	REVISED -
PLOT DATE = 10/19/2011	CHECKED - BLM	REVISED -
	DATE - 10/14/11	REVISED -

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

**TEMPORARY LIGHTING PLAN
IL 75 RAMP C**

SCALE:	SHEET NO.	OF	SHEETS	STA.	TO STA.
--------	-----------	----	--------	------	---------

F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
90	(X2-1)R	WINNEBAGO	510	261
CONTRACT NO. 64C29				
ILLINOIS FED. AID PROJECT				