


NOTE:
 CONTRACTOR MUST LOCATE EXISTING UNIT DUCT BEFORE REMOVING AND REPLACING EXISTING LIGHT POLE AND FOUNDATION.

- LEGEND:
- EXISTING UNIT DUCT
 - - - PROPOSED UNIT DUCT
 - ⊗ EXISTING LIGHT POLE TO REMAIN UNLESS NOTED OTHERWISE
 - PROPOSED LIGHT POLE, WEATHERING STEEL, 45 FT. M.H., TENON MOUNT WITH (1) 400W HPS VAPOR MM FIXTURE
 - 1 UNIT DUCT, 600V, 2-1C NO.6, 1/C NO.6 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE



	USER NAME = _USERNAME_	DESIGNED - BLM	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	LIGHTING PLAN VISITOR CENTER EXIT RAMP			F.A.I. RTE. 90	SECTION (X2-1R)	COUNTY WINNEBAGO	TOTAL SHEETS 510	SHEET NO. 270
		PLOT SCALE = 50.0000' / IN.	DRAWN - JPW		REVISED -	SCALE:	SHEET NO. OF SHEETS	STA. TO STA.	CONTRACT NO. 64C29			
	PLOT DATE = 10/19/2011	CHECKED - BLM	REVISED -		ILLINOIS FED. AID PROJECT							
		DATE - 10/14/11	REVISED -									