


NOTE:
CONTRACTOR MUST LOCATE EXISTING UNIT DUCT BEFORE REMOVING AND REPLACING EXISTING LIGHT POLE AND FOUNDATION.

- LEGEND:
- EXISTING UNIT DUCT
 - PROPOSED UNIT DUCT
 - EXISTING LIGHT POLE TO REMAIN UNLESS NOTED OTHERWISE
 - PROPOSED LIGHT POLE, WEATHERING STEEL, 45 FT. M.H., TENON MOUNT WITH (1) 400W HPS VAPOR MM FIXTURE
 - UNIT DUCT, 600V, 2-1C NO.6, 1/C NO.6 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE



USER NAME = .USERNAME.	DESIGNED - BLM	REVISED -
PLOT SCALE = 50,0000' / IN.	DRAWN - JPW	REVISED -
PLOT DATE = 10/19/2011	CHECKED - BLM	REVISED -
	DATE - 10/14/11	REVISED -

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

LIGHTING PLAN			
VISITOR CENTER ENTRANCE RAMP			
SCALE:	SHEET NO. OF SHEETS	STA. TO STA.	

F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
90	(X2-1)R	WINNEBAGO	510	272
CONTRACT NO. 64C29			ILLINOIS FED. AID PROJECT	