



* UPDATED VALUES TO COMPLY WITH ISTHA GUIDELINES FOR ROADWAY ILLUMINATION (JULY 2007), VALUES TO USE FOR VOLTAGE DROP CALCULATIONS:

400W HPS = 1AMP
150W HPS = 0.4AMP

EL-10

DRAWN BY JDM	DATE 05-22-08	EJM ENGINEERING, INC. 411 South Wells Street Suite 800 Chicago, Illinois 60607	THE ILLINOIS STATE TOLL HIGHWAY AUTHORITY 2700 OGDEN AVENUE DOWNERS GROVE, ILLINOIS 60515	REVISIONS NO. DATE DESCRIPTION		CONTRACT NO. I-08-5544 LOAD TABULATIONS	DRAWING NO. 137 OF 186
CHECKED BY JH	DATE 05-22-08						