



STA. 0+073
UNDERGROUND CONDUIT, PVC, 2" DIA. - 120 FEET

- NOTES:
1. PROPOSED LIGHT POLES SHALL BE INSTALLED AT AN OFFSET OF 23 FEET WITH RESPECT TO THE ADJACENT RAMP ALIGNMENT. NO POLES TO BE INSTALLED IN THE FLOWLINE OF DITCH. POLE SETBACK TO BE INCREASED IF NECESSARY AS DIRECTED BY THE ENGINEER.
 2. UNDERGROUND CONDUIT SHALL BE PVC SCHEDULE 80.

LEGEND

- ELECTRIC SERVICE INSTALLATION, 240/480V, ONE PHASE, 4 WIRE
- LIGHTING CONTROLLER, 60A, 480V
- LIGHT POLE, WEATHERING STEEL, 45 FT. M.H., TENON MOUNT WITH 250W HPS MULTI-MOUNT LUMINAIRE
- UNIT DUCT IN TRENCH, 600V, 2-1C NO. 6, 1/C NO. 8 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE
- EXISTING UNIT DUCT
- EXISTING LIGHTING UNIT
- STEEL PLATE BEAM GUARDRAIL, TYPE A, 6FT POSTS
- UNDERGROUND CONDUIT, SIZE AND TYPE AS INDICATED

STA. 0+590
UNDERGROUND CONDUIT, PVC, 2" DIA. - 44 FEET

STA. 0+750
UNDERGROUND CONDUIT, PVC, 2" DIA. - 44 FEET

FILE NAME :	USER NAME :	DESIGNED -	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	LIGHTING PLANS			F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
	PLOT SCALE :	CHECKED -	REVISED -					310	169-11L-1	MORGAN	17	6
PLOT DATE :	DATE -	REVISED -	REVISED -	SCALE:	SHEET NO.	OF SHEETS	STA.	TO STA.	CONTRACT NO. 72E13 ILLINOIS FED. AID PROJECT			