


TRANSPORTATION BULLETIN



Illinois Department of Transportation

ADDENDUM NO. 1

Dated: January 12, 2012

For: Transportation Bulletin
Volume 11 No. 49r

Dated: December 9, 2011, Revised: January 10, 2012

Letting Date: January 20, 2012

Item No. 9A – Upgrade Perimeter Fence – Phase 4

Central Illinois Regional Airport

McLean County, Illinois

IL Project No.: BMI-4098

AIP Project No.: 3-17-0006-XX

Contract No.: BL067

REASON FOR ADDENDUM:

Revisions to fence specification Item AR162 for gate operator and clarifications to specifications.

Clarifications to items on plan sheets.

TO ALL PLAN HOLDERS:

REVISE CONTRACT DRAWINGS

DRAWING NO. 9:

CLARIFY:

Clarified existing 10' fence location that is not part of this project.

DRAWING NO. 12:

REVISE:

Revised call out of new electric gate to **AR162720**.

CLARIFY:

Clarified the start of the new 10' fence.

DRAWING NO. 13:

REVISE:

Revised legend and fence symbol to clarify the 8' fence.

DRAWING NO. 14:

REVISE:

Revised legend and fence symbol to clarify the 8' fence.

DRAWING NO. 15:

REVISE:

Revised legend to clarify the 8' fence.

DRAWING NO. 16:

REVISE:

Revised call out of new electric gate to **AR162724**.

DRAWING NO. 17:

CLARIFY:

Clarified the end of the new 10' fence.

DRAWING NO. 20:

REVISE:

Revised note on fence installation at ground line. Note now reads: **“Fence shall be installed at or below (-3”) ground line. Gap in detail shown for clarity.**

DRAWING NO. 34:

REVISE:

Keyed Note #8, First Sentence to read:

NEW CANTILEVER SLIDE GATE MOTOR OPERATOR, **LINEAR/OSCO MODEL HSLG-1**, 1 HP, 120V, SINGLE PHASE, OR EQUIVALENT, SUITABLE FOR A MAXIMUM GATE WEIGHT OF **1700** LBS AND MAXIMUM GATE WIDTH OF **55** FEET.

DRAWING 35:

REVISE:

Keyed Note #1, First Sentence to read:

NEW CANTILEVER SLIDE GATE MOTOR OPERATOR, **LINEAR/OSCO MODEL HSLG-1**, 1 HP, 120V, SINGLE PHASE, OR EQUIVALENT, SUITABLE FOR A MAXIMUM GATE WEIGHT OF **1700** LBS AND MAXIMUM GATE WIDTH OF **55** FEET.

DRAWING 36:

REVISE:

Keyed Note #1, Second Paragraph, First Sentence to read:

NEW CANTILEVER SLIDE GATE MOTOR OPERATOR, **LINEAR/OSCO MODEL HSLG-1**, 1 HP, 120V, SINGLE PHASE, OR EQUIVALENT, SUITABLE FOR A MAXIMUM GATE WEIGHT OF **1700** LBS AND MAXIMUM GATE WIDTH OF **55** FEET.

DRAWING 37:

REVISE:

Keyed Note #1, First Sentence to read:

NEW CANTILEVER SLIDE GATE MOTOR OPERATOR, **LINEAR/OSCO MODEL HSLG-1**, 1 HP, 120V, SINGLE PHASE, OR EQUIVALENT, SUITABLE FOR A MAXIMUM GATE WEIGHT OF **1700** LBS AND MAXIMUM GATE WIDTH OF **55** FEET.

REVISE SPECIAL PROVISIONS

NOTICE TO BIDDERS, ITEM 162 Chain Link Fences p. 25-34

Paragraph 162-2.1 Fabric

REVISE:

The color of the **vinyl** coating shall be black and shall meet the approval of the Engineer. **The vinyl coating applies to all fence fabric, rails, posts, braces, stretcher bars, couplings, ties and other miscellaneous materials for Alternate #1 only.**

Paragraph 162-2.3

Motorized Gate Operators

REVISE: Item A to read:

A. The Contractor shall furnish and install electric chain drive gate operators, **Linear/Osco Model HSLG-1**, 1 HP, 120V, Single-Phase, or equivalent. Gate operator shall capable of opening a maximum gate weight of at least **1700** lbs and maximum gate width of **55** feet. NOTE: At Terminal Building East & West Gates (Gate #4 & #7), provide gate operator matching existing voltage and phases.

LOAD CENTERS

ADD: The following to Item A:

Provide 20A, 1P circuit breaker for Gate Operator, 20A, 1P circuit breaker for Area Light, 20A, 1P circuit breaker for Access Control Equipment, minimum of two 20A, 1P "Spare" circuit breakers.