



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

January 27, 2015

SUBJECT: Various
Section 09-00020-00-RS (Petersburg)
Menard County
Contract No. 93627
Item 40
January 30, 2015 Letting
Addendum (A)

NOTICE TO PROSPECTIVE BIDDERS:

Due to clarify information necessary to revise the following:

- 1. Revised page 3 of the Schedule of Prices.**
- 2. Revised page 7 of the Special Provisions.**
- 3. Revised sheets 2, 3, 44, 45, & 46 of the plans.**

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

John Baranzelli, P.E.
Acting Engineer of Design and Environment

A handwritten signature in cursive script, reading "Ted B. Walschleger P.E.", with a small "P.E." to the right.

By: Ted B. Walschleger, P.E.
Engineer of Project Management

| ITEM NUMBER | PAY ITEM DESCRIPTION | UNIT OF MEASURE | QUANTITY | UNIT PRICE | | TOTAL PRICE | |
|-------------|----------------------|-----------------|--------------|------------|-------|-------------|-----|
| | | | | DOLLARS | CENTS | DOLLARS | CTS |
| 40600990 | TEMPORARY RAMP | SQ YD | 192.000 X | = | = | = | = |
| 40603310 | HMA SC "C" N50 * | TON | 389.000 X | = | = | = | = |
| 42000564 | PCC PVT 14 JOINTED | SQ YD | 328.000 X | = | = | = | = |
| 4200130C | PROTECTIVE COAT | SQ YD | 1,251.000 X | = | = | = | = |
| 42300400 | PCC DRIVEWAY PAVT 8 | SQ YD | 48.000 X | = | = | = | = |
| 42400100 | PC CONC SIDEWALK 4 | SQ FT | 6,992.000 X | = | = | = | = |
| 42400800 | DETECTABLE WARNINGS | SQ FT | 349.000 X | = | = | = | = |
| 44000100 | PAVEMENT REM | SQ YD | 4,722.000 X | = | = | = | = |
| 44000157 | HMA SURF REM 2 | SQ YD | 1,815.000 X | = | = | = | = |
| 44000300 | CURB REM | FOOT | 1,271.000 X | = | = | = | = |
| 44000600 | SIDEWALK REM | SQ FT | 15,496.000 X | = | = | = | = |
| 44003100 | MEDIAN REMOVAL | SQ.FT | 273.000 X | = | = | = | = |
| 550A0050 | STORM SEW CL A 1 12 | FOOT | 56.000 X | = | = | = | = |
| 55100500 | STORM SEWER REM 12 | FOOT | 7.000 X | = | = | = | = |
| 56300300 | ADJ WATER SERV LINES | FOOT | 600.000 X | = | = | = | = |

* Revised 1/27/15

Compensation for full depth saw cuts and manual methods of sidewalk removal will be included in the unit cost bid price for SIDEWALK REMOVAL.

FIRE HYDRANTS TO BE ADJUSTED

This item shall consist of furnishing all labor, equipment and materials necessary for the complete adjustment of the existing fire hydrants at locations shown on the Plans and as directed by the Engineer. The work shall be done in accordance with the applicable portions of Section 564 of the Standard Specifications.

Basis of Payment. This work will be paid for at the contract unit price per each for FIRE HYDRANTS TO BE ADJUSTED which price shall be payment in full to complete the work as herein specified.

ORNAMENTAL LIGHT UNIT, COMPLETE

This work consists of furnishing and installing decorative poles and decorative luminaries and making all electrical connections as shown in the plans and directed by the Engineer.

Direct embedment of the poles shall not be allowed. Poles shall be mounted on a concrete foundation as per these special provisions and Section 878 of the Standard Specifications.

Submittals. The following items shall be submitted and approved prior to operations: product cut sheets.

Method of Measurement. This work will be measured as each, where each is defined as a light pole, decorative base, luminaire, receptacle, wirings, and any other related components.

Basis of Payment. This work will be paid for at the contract unit price per each for ORNAMENTAL LIGHT UNIT, COMPLETE.

PORTLAND CEMENT CONCRETE SIDEWALK 6 INCH, SPECIAL

This work shall be in accordance with Section 424 of the Standard Specifications, the details in the plans, and as specified herein.

This work consists of constructing sidewalk with an exposed aggregate finish with and without reinforcement over sidewalk vaults as detailed in the plans.

Coarse aggregate for exposed aggregate finish for cast-in-place concrete surfaces shall be river gravel, exclusive of crushed gravel and rock. The maximum diameter of the river gravel shall be 3/8".

The surface shall receive a chemical retarder specifically designed to produce uniform exposed aggregate finishes on horizontal surfaces in accordance with the manufacturer's instructions.

After the concrete has cured seven (7) days, it shall receive an application of curing and sealing compound meeting AASHTO M 148, Type 1, Class A & B.

Test Panel. A test panel at least 4.0' x 4.0' in size shall be successfully completed at a location approved by the Engineer before beginning work on the exposed aggregate finishes. The test panel shall be constructed and finished with the materials, tools, equipment and methods to be used in constructing the exposed aggregate finish. If ordered by the Engineer, up to a maximum of two (2) additional test panels