



GENERAL NOTES

PLAN DIMENSIONS AND DETAILS RELATIVE TO EXISTING PLANS ARE SUBJECT TO ROUTINE VARIATIONS. THE CONTRACTOR SHALL FIELD VERIFY EXISTING DIMENSIONS AND DETAILS AFFECTING NEW CONSTRUCTION AND MAKE NECESSARY APPROVED ADJUSTMENTS PRIOR TO CONSTRUCTION OR ORDERING OF MATERIALS. SUCH VARIATIONS SHALL NOT BE CAUSE FOR ADDITIONAL COMPENSATION FOR A CHANGE IN SCOPE OF THE WORK, HOWEVER, THE CONTRACTOR WILL BE PAID FOR THE QUANTITY ACTUALLY FURNISHED BASED UPON THE UNIT PRICE BID FOR THE WORK.

THIS WORK WILL BE PAID FOR AT THE CONTRACT UNIT PRICE PER CUBIC YARD FOR CONCRETE STRUCTURES.

THE COST OF EPOXY GROUTING THREADED RODS SHALL BE INCLUDED WITH REINFORCEMENT BARS (EPOXY COATED).

REINFORCEMENT BARS SHALL CONFORM TO THE REQUIREMENTS OF ASTM A706 OR 6011L MODIFIED.

REINFORCEMENT BARS DESIGNATED (E) SHALL BE EPOXY COATED.

TAPERED CRASHWALL EXTENSION (SIX CIRCULAR COLUMN PIER)																					
CONCRETE STRUCTURES				BAR					BAR					BAR							
STRUCTURE STATION	DIMENSION B (FT)	DIMENSION C (FT)	STRUCTURES (CU YD)	BAR	QTY	SIZE	LENGTH	SHAPE	LBS	BAR	QTY	SIZE	LENGTH	LBS	BAR	QTY	SIZE	LENGTH	LBS		
092-0038	2'-5"	1'-7"	15.3	h(E)	60	#5	2'-9"		172.1	h16(E)	28	#5	13'-2"	384.5	h17(E)	7	#5	10'-9"	78.5		
1929+29.04																					
CONCRETE STRUCTURES =			15.3	LBS =					172.1	LBS =					384.5	LBS =					78.5
				s19(E)	44	#5	10'-5"		460.8	s(E)	88	#5	2'-0"	183.6	REINFORCEMENT BARS (EPOXY COATED) =					1279.5	
									460.8										183.6		

NOTE:
WORK TO BE DONE TO CENTER PIER ONLY.