



- CONSTRUCTION NOTE:**
- 1) UNLESS OTHERWISE NOTED, SPACING SHALL BE 15 FT. BETWEEN TRANSVERSE JOINTS.
 - 2) SPACING BETWEEN TRANSVERSE JOINTS AT INLETS SHALL BE 13 FT.
 - 3) JOINTS SHALL BE CONSTRUCTED IN ACCORDANCE WITH IDOT STD. 420001-06.

