



Stainless steel standard grade wire cloth, 6x6 (1/4") mesh or less with #16 gauge (0.062") diameter or heavier wire.

Attach with 1/2" stainless steel banding or tie back on itself with stainless steel wire ties. Finished installation must prevent rodent entry.

Pole ground lug
Wireway window in pole foundation

Surge protectors (metal oxide-varistor type)

2-1/2" #10 XLP-USE cable to each luminaire

For each luminaire use 2 pole fused quick disconnect. For receptacle circuit (not shown) use 2 pole fuseholder with solid neutral.

Pole base plate
1" leveling nuts

WIRING DETAIL

NO SCALE

GENERAL NOTES

All taped splices shall use 2 layers of electrical tape over 3 layers of rubber tape as required by the Standard Specifications. Coat the finished taped splice with bonding compound.

All cable splices shall be taped unless another method has been specifically approved by the Engineer.

For example purposes the pole is shown on an anchor base. If the pole is required to be set on a breakaway base, consult the Standard Specifications.

All dimensions are in millimeters (Inches) unless otherwise shown.

DATE	REVISIONS	POLE HANDHOLE WIRING
7/31/08	Updated	
		<h1>DRAFT</h1>

LGTO08A.DGN