


DESIGNED BY: \_\_\_\_\_ CHECKED BY: \_\_\_\_\_  
 H.A.R. \_\_\_\_\_ CHECKED BY: \_\_\_\_\_  
 DRAWN BY: \_\_\_\_\_

**NOTES:**

1. SEE SHEET NUMBER E-1 FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES.
2. 12" x 8" x 8" PULLBOX EMBEDDED IN FLOODWALL ABOVE SHEET PILE.
3. 1-1/2" RGS CONDUIT EMBEDDED IN FLOODWALL. INSTALL CONDUIT FOR MOUNTING FLOOD WALL LUMINAIRE 9'-5" ABOVE THE BIKE TRAIL PAVEMENT. SEE DETAIL ON SHEET E-2.
4. COORDINATE ELECTRIC SERVICE WITH COMWE.

**CABLE GROUPINGS SCHEDULE**

- A 6-1/C #6 & 1-1/C #8 GROUND IN 2" PVC CONDUIT EMBEDDED IN FLOOD WALL



REVISION	
DATE	DESCRIPTION

PLANS PREPARED BY:  
**CTE | AECOM**

CTE  
303 East Wacker Drive, Suite 600, Chicago, Illinois 60601-5276  
T 312.938.0300 F 312.938.1109 www.cte.aecom.com

FR-416

01/30/2006 07:40:01 PM p:\p50003332\elect\shf\06E-04.sht