


JAN 12, 2006 1:33 PM CAH
 I:\AIRPORTS\METROPOLIS\B16-06VLT\AIRPORT\SHEETS\R-101SIT.DWG - EXIST. SITE



THE LOCATION, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ON THE PLANS IS NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.

CALL J.U.L.I.E. FOR UTILITY INFORMATION AT 1-800-892-0123.

LEGEND MP002

- EXISTING PAVEMENT
- EXISTING BUILDINGS
- EXISTING FENCE
- EXISTING TELEPHONE LINE
- EXISTING GAS LINE
- EXISTING AIRFIELD LTG CABLES
- EXISTING OVERHEAD ELECTRIC
- EXISTING UNDERGROUND ELECTRIC
- EXISTING ELECTRICAL DUCT MARKERS
- EXISTING GUY WIRE
- EXISTING SEPTIC TANK
- EXISTING ROTATING BEACON
- EXISTING ELECTRICAL VAULT
- EXISTING POWER POLE
- EXISTING LIGHT POLE
- EXISTING FIRE HYDRANT
- EXISTING WATER VALVE

#8 AWG, 5 KV HOMERUN CABLES FOR RUNWAY & TAXIWAY LIGHTING

SEPTIC TANK. CONTRACTOR SHALL FIELD VERIFY LATERAL LINES AS APPLICABLE FOR NEW VAULT INSTALLATION.

ABANDONED WIND CONE CIRCUIT CABLES

CONTROL CABLE TO L-821 PANEL IN ADMIN BLDG

AIRPORT ROTATING BEACON

FENCE

VAULT TRANSCLOSURE

GUY WIRE TERMINATION (TYP. FOR 3)

ELECTRIC UTILITY POLE

ROADWAY POLE LIGHT

AIRPORT ENTRANCE ROAD

SATELLITE DISH

UTILITY TRANSFORMER POLE WITH SERVICE DISCONNECT FOR VAULT

WATER VALVE

WATER HYDRANT

CAR PORT

DATE	REVISION	BY

**METROPOLIS MUNICIPAL AIRPORT
 METROPOLIS, ILLINOIS**

A.I.P. PROJ.: 3-17-0067-88
 I.L. PROJ.: M30-3541

REV. PROJECT No. 816-06VLT.D 0800	11/15/05
FILENAME: R-101SIT.DWG	MDR
SCALE: 1"=10'	MDR
DATE: 11/15/05	CAH
LAYOUT	11/15/05
DRAWN	11/15/05
REVIEWED	12/16/05



**CONSTRUCT
 NEW VAULT**

**EXISTING
 AIRPORT VAULT
 SITE PLAN**

