



**WIND CONE NOTES**

1. THE PROPOSED WIND CONE SHALL BE INSTALLED AS SHOWN ON SHEETS 13, 14, & 19 AND IN ACCORDANCE WITH THE SPECIAL PROVISIONS.
2. CONNECT NEW POWER CABLES TO EXISTING RWY 5 WIND CONE CABLES AT SPLICE CAN. DO NOT CONNECT TO RWY 5 WIND CONE CIRCUIT. EXISTING POWER SOURCE & EXISTING CONTROL PANEL FOR RWY 15 WIND CONE ARE LOCATED AT THE FIRE STATION ACCESS ROAD OFF OF RWY 5. TURN OFF POWER WHEN WORKING ON CIRCUIT INTERFACE & CONNECTION. LOCATE BOOST TRANSFORMER AT EXISTING CONTROL PANEL.
3. THE PROPOSED POWER CABLE FROM THE RESPECTIVE INTERFACE POINT/SPLICE CAN TO THE WIND CONE WILL BE PAID FOR UNDER ITEM: AR108658 3/C #8, 600V UG CABLE IN UD PER L.F.

**LEGEND**

- EXISTING PAVEMENT
- PROPOSED POWER CABLE
- EXISTING WIND CONE
- PROPOSED WIND CONE
- PROPOSED CABLE MARKER

**LEGEND**

0' 50' 100' 200'

FULL SIZE SCALE: 1" = 100'  
 HALF SIZE SCALE: 1" = 200'

THE LOCATION, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ON THE PLANS IS NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.

CALL J.U.L.I.E. FOR UTILITY INFORMATION AT 1-800-892-0123. CONTACT AIRPORT PERSONNEL FOR ASSISTANCE IN LOCATING AIRPORT CABLES. CONTACT FAA FOR ASSISTANCE IN LOCATING FAA CABLES

QUANTITIES				
ITEM No.	DESCRIPTION	UNIT	QUANTITY	AS BUILT QUANTITY
AR107408	L-806 WIND CONE-8' LIGHTED	EA.	1	
AR108658	3/C #8 600V UG CABLE IN UD	L.F.	2,027	

DATE	REVISION	BY

MT. VERNON AIRPORT  
 MT. VERNON, ILLINOIS  
 I.L. PROJ.: MVN-3539 A.I.P. PROJ.: 3-17-0074-B12

PROJECT No.	DATE	BY	REVIEWED
819-06RWYD	08/16/05	CCC	CCC
R-14 TELE.DWG	08/16/05	CCC	CCC
Scale 1" = 100'	08/16/05	RAW	RAW

**HANSON**  
 Hanson Professional Services Inc.  
 1525 South Sixth Street  
 Springfield, Illinois 62703-2886  
 Offices Nationwide

**RUNWAY 15-33  
 P.F.C. OVERLAY  
 PROPOSED  
 ELECTRICAL PLAN**

JAN 19, 2006 8:31 PM RAW  
 I:\AIRPORTS\MVERNON\819-06RWYD\AIRPORT\SHEETS\R-141ELE.DWG - Wind Cone Layout