CONTRACT NO. 64647

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
595	1-3-K	ROCK ISLAND	476	180
STA.	TO STA.			
FED. ROAD DIST. NO.	ILLINOIS	FED. AID PROJECT		

PLAN — DRAWN / PLOTTED / ALIGNMENT CHECKED / GRADES CHECKED / CADD FILE NAME / NOTE BOOK / NO. / BY / DATE

PROFILE — DRAWN / PLOTTED / GRADES CHECKED / QUANTITIES / STRUCTURE NO'S/ATN'S CHKD / BY / DATE

N

HISTORY BUILDING

POT Sta. 0+00.00

0+00

SEE SHEET 1 FOR WATER MAIN DETAILS

3RD STREET

PROP. VALVE GATE, 8" MJRW & BOX, TEE, DIMJ, 8"x 6", VALVE GATE, 6" MJRW & BOX 5 L.F. DIWM, 6" & 6" FIRE HYDRANT (SEE DETAIL THIS SHEET)

PC Sta. 3+22.98

TAP & CORP., 1" FOR TESTING
PROP. TEE, DIMJ 8"x 6"
PROP. VALVE GATE 8" MJRW & BOX
PROP. BENDS, DIMJ 45°& 11 1/4°, 8"
CUT & PLUG MJ, 8"
PROP. DIWM, 8"
PROP. VALVE GATE, 6" MJRW & BOX
PROP. 6" FIRE HYDRANT
EXIST. DIWM, 8"

DETAIL (NO SCALE)

PROP.BENDS, DIMJ, 45°& 11 1/4°, 8", COUPLING 8" (SEE DETAIL THIS SHEET)

CUT & PLUG MJ, 8" AFTER NEW WM IS IN SERVICE

SEE DETAIL, THIS SHEET

℄ OF PROP. DIWM, 8"

DEFLECT PIPE JOINTS

PROP. STORM SEWER
FL = 567.57

FL = 567.65

FL = 567.51

PROP. 4' MAN GATE

MATCH LINE STA. 5+80

PROP. STORM SEWER STA. 5+42.60

5+00

℄ PROP. SAN. SEW. D.I.P. PCL 350 8"

PLUG EXIST. SAN. SEWER AFTER NEW SAN. SEWER IS IN SERVICE

SAN. M.H. 4' DIA, 11, F&C
37.95' RT 4+65.55

PROP. 4' MANHOLE
INV. E. = 564.66 (EXIST.)
INV. E. = 564.47 (PROP.)
T.O.P. = 571.43

EXIST. GROUND ALONG PROP. WATER MAIN

EXIST. GROUND ALONG PROP. SAN. SEWER

3RD STREET

PROP. 24" STORM SEWER @ PROP. 12" WM CROSSING

18" MIN.

5' MIN. COVER (TYPICAL)

563.97

125 L.F. 8" SAN. SEWER @ 0.4%

585 575 565 555 545

3RD STREET – STA. 0+00 TO STA. 5+80

IEPA PERMIT SUBMITTAL SHEET 2 OF 7