


NOTES

1. ALL LUMINAIRE MOUNTING HEIGHTS ARE 30'.
2. ALL PROPOSED UNIT DUCTS ARE 1" DIA. POLYETHYLENE WITH (3) 1/C #4 AND (1) 1/C#6 GND (EPR-TYPE RHW).
3. POLE FOUNDATIONS SHALL BE 30" DIAMETER IN ACCORDANCE WITH IDOT STANDARD DRAWING BE-301 EXCEPT BOLT CIRCLE DIAMETER SHALL MATCH HOLE SPACING OF POLES.
4. ALL LUMINAIRES SHALL HAVE 250W HPS LAMPS.



LT-04
63415

REVISIONS / REMARKS					
NO.	DESCRIPTION	DATE	BY	DESIGNED BY:	DL
		/ /		CHECKED BY:	IB
		/ /		DATE:	01/22/10

SPAAN Tech, Inc.
311 South Wacker Drive, Suite 2400
Chicago, IL 60606
Phone: 312.277.8800
Fax: 312.277.8888
www.spaan-tech.com

HDR
38 N LaSalle Street, Suite 3220
Chicago, IL 60652
312-443-4900
HDR Engineering, Inc.

 **LakeCounty**
Division of Transportation

**RIVERWOODS AND EVERETT ROADS
PROPOSED ROADWAY LIGHTING PLAN**

ROUTE	SECTION	SECTION NUMBER	SHEET	SHEETS
CH	136	04-00136-06-CH	66	107

FILE NAME: