



F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
80	50-3HBK	LASALLE	492	259

ILLINOIS FED. AID PROJECT



MATCH LINE STA. 125 + 00

NOTE:
CONDUIT PUSHED SHALL BE PVC SCHEDULE 80 AND SHALL BE ACCORDING TO SECTION 810.



- LEGEND**
- PROPOSED LIGHT TOWER, 100 FT MOUNTING HEIGHT, 6 OR 4 400w HPS LUMINAIRES
 - PROPOSED LIGHTING UNIT, 50 FT ALUMINUM POLE, 15 FT DAVIT ARM, 400w HPS LUMINAIRE, M-C-III
 - PROPOSED LIGHTING CONTROLLER
 - SERVICE INSTALLATION
 - PROPOSED UNIT DUCT
 - CONDUIT PUSHED, PVC, DIA. AS NOTED
 - JUNCTION BOX, STAINLESS STEEL, ATTACHED TO STRUCTURE

- CABLE / CONDUIT SCHEDULE**
- (A) UNIT DUCT, 600V, 2 - 1C NO. 6, 1/C NO.8 GROUND, (XLP - TYPE USE), 1" DIA. POLYETHYLENE
 - (B) UNIT DUCT, 600V, 2 - 1C NO.4, 1/C NO.6 GROUND (XLP - TYPE USE), 1" DIA. POLYETHYLENE
 - (C) UNIT DUCT, 600V, 2 - 1C NO. 2, 1/C NO.4 GROUND, (XLP - TYPE USE), 1/4" DIA. POLYETHYLENE

REVISIONS	
NAME	DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION
PROPOSED LIGHTING

PLOT DATE = Feb 18, 2010 - 01:39:05 PM
FILE NAME = c:\pwork\p\PROJECT\CARPENTER\J\cma414193\EP06582-shr-light.dgn
USER NAME = carpenterj