

STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths				
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4
3, 4	1'-5''	1'-11''	2'-1"	2'-4"
5	1'-9''	2'-5"	2'-7"	2'-11''
6	2'-1"	2'-11"	3'-1''	3'-6"
7	2'-9"	3'-10''	4'-2"	4'-8''
8	3'-8''	5'-1"	5′-5″	6'-2"
9	4'-7''	6'-5"	6'-10''	7′-9′′

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C


Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Threaded splicer bar length = min. lap length + I_2'' + thread length

* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar size	No. assemblies required	Table for minimum lap length
S. Abutment	#5	18	3
S. Abutment	#6	4	3
	İ		




BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required =

DESIGNED GGE	March 15, 2010		
CHECKED I.J.L.	EXAMINED & Carl Prayey		
DRAWN Drew Christopher	PASSED Ralph E. andersa		
CHECKED GGE I.J.L.	ENGINÉER OF BRIDGES AND STRUCTURES		
BSD-1	11-1-09		


STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION




INSTALLATION AND SETTING METHODS

"A": Set bar splicer assembly by means of a template bolt.
"B": Set bar splicer assembly by nailing to wood forms or cementing to steel forms.

(E): Indicates epoxy coating.





STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required		

<u>NOTES</u>

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi yield strength.

All reinforcement shall be lapped and tied to the splicer bars.

Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications.

See special provision for Mechanical Splicers. See approved list of bar splicer assemblies and mechanical splicers for

alternatives.

BAR SPLICER DETAILS SN 090-0110

					***		•	
	SHEET NO. 4		F.A.P. RTE.	SECTION		COUNTY	TOTAL SHEETS	SHEET NO.
			673	101RS-3, 102RS-4, 103RS-4, 104RS-7		Tazewell	60	31
						CONTRACT	NO. 6	8920
	F			DAD DIST. NO.	ILLINOIS FED. A	D PROJECT		

0900110.dgn 3/15/2010 8: 41: 19 AM

SLT-94-001-10