


EXISTING LIGHTING CONTROLLER "R"
CONNECT INTO EXISTING LIGHTING CONTROLLER NOTES 2 & 4

NOTES:

1. EXTEND EXISTING UNIT DUCT AND ROUTE INTO NEW FOUNDATION OR NEW HANDHOLE. REUSE EXISTING WIRING IF LENGTH IS SUFFICIENT. IF NOT, REMOVE EXISTING WIRING BACK TO NEXT FOUNDATION/HANDHOLE AND INSTALL NEW 1/C #6, 1/C #6 NEUTRAL & 1/C #6 GROUND. REMOVING EXISTING CABLE IN CONDUIT WILL NOT BE PAID FOR SEPARATELY, CONTRACTOR MAY SALVAGE REMOVED WIRE. SPLICING NEW WIRING IN EXISTING LIGHT POLES/HANDHOLES WILL BE PAID FOR "CABLE SPLICING, SPECIAL".
2. CONTRACTOR SHALL TAKE FULL MAINTENANCE OF EXISTING LIGHTING CONTROLLERS "B", "C", "Q", & "R". SEE SPECIAL PROVISIONS.
3. REMOVING EXISTING HANDHOLE AND REPLACING WITH NEW HANDHOLE SHALL BE PAID FOR UNDER "RELOCATE EXISTING HANDHOLE".
4. CONTRACTOR SHALL MODIFY EXISTING LIGHTING CONTROLLER TO ACCEPT A NEW BRANCH CIRCUIT. SEE DETAILS AND SPECIAL PROVISIONS FOR MORE INFORMATION.
5. REMOVE, DISASSEMBLE AND STORE EXISTING LIGHTPOLE, AND REMOVE CONCRETE FOUNDATION PRIOR TO THE REPLACEMENT OF SEWER. IMMEDIATELY AFTER SEWER WORK IS COMPLETE, REINSTALL EXISTING LIGHTPOLE ON NEW CONCRETE FOUNDATION.
6. REMOVE EXISTING CONDUIT AND WIRE PRIOR TO THE REPLACEMENT OF SEWER. INSTALL NEW 1/4" SCH 40 HDPE CONDUIT WITH 1/C #6, 1/C #6 NEUTRAL AND 1/C #6 GROUND IMMEDIATELY AFTER SEWER WORK IS COMPLETE.



MATCH LINE STA. 119+00

MATCH LINE STA. 125+00

FILE NAME = N:\FORESTPARK\070082\Mech\LG1_070082.dwg	USER NAME = JBARNETT	DESIGNED -	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	ROADWAY LIGHTING IMPROVEMENTS - HARVARD ST. LIGHTING PLAN (1 OF 2)	F.A.U. RTE. 1702	SECTION 07-00106-00-PV	COUNTY COOK	TOTAL SHEETS 75	SHEET NO. 42		
PLOT SCALE = 20"	PLOT DATE = 2/19/2004	DRAWN -	REVISED -			SCALE:	SHEET NO. OF SHEETS STA. TO STA.	CONTRACT NO. 63148				
CHECKED -	REVISED -	FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT										
DATE -	REVISED -											