



**NOTES:**

1. EXTEND EXISTING UNIT DUCT AND ROUTE INTO NEW FOUNDATION OR NEW HANDHOLE. REUSE EXISTING WIRING IF LENGTH IS SUFFICIENT. IF NOT, REMOVE EXISTING WIRING BACK TO NEXT FOUNDATION/HANDHOLE AND INSTALL NEW 1/C #6, 1/C #6 NEUTRAL, & 1/C #6 GROUND. REMOVING EXISTING CABLE IN CONDUIT WILL NOT BE PAID FOR SEPARATELY. CONTRACTOR MAY SALVAGE REMOVED WIRE. SPLICING NEW WIRING IN EXISTING LIGHT POLES/HANDHOLES WILL BE PAID FOR "CABLE SPLICING, SPECIAL".
2. CONTRACTOR SHALL TAKE FULL MAINTENANCE OF EXISTING LIGHTING CONTROLLERS "B", "C", "Q", & "R". SEE SPECIAL PROVISIONS.
3. REMOVING EXISTING HANDHOLE AND REPLACING WITH NEW HANDHOLE SHALL BE PAID FOR UNDER "RELOCATE EXISTING HANDHOLE".
4. CONTRACTOR SHALL MODIFY EXISTING LIGHTING CONTROLLER TO ACCEPT A NEW BRANCH CIRCUIT. SEE DETAILS AND SPECIAL PROVISIONS FOR MORE INFORMATION.

FILE NAME = N:\FORESTPARK\070082\Mech\LG1_070082_02.SHT	USER NAME = JBARNETT	DESIGNED -	REVISED -	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>ROADWAY LIGHTING IMPROVEMENTS - HARVARD ST. LIGHTING PLAN (2 OF 2)</b>	F.A.U. RTE. 1702	SECTION 07-00106-00-PV	COUNTY COOK	TOTAL SHEETS 75	SHEET NO. 43	
PLOT SCALE = 20'		CHECKED -	REVISED -			SCALE: SHEET NO. OF SHEETS STA. TO STA.					
PLOT DATE = 2/18/2009		DATE -	REVISED -			FED. ROAD DIST. NO. 1   ILLINOIS FED. AID PROJECT					
CONTRACT NO. 63148											