



LEGEND:
 --- EXISTING UNDERGROUND CONDUCTORS
 // // EXISTING UNDERGROUND CONDUCTORS - TO BE ABANDONED.
 □ EXISTING LIGHTING UNIT.

KEYED NOTES:
 ① EXISTING LIGHTING UNIT TO BE RELOCATED.
 ② DISCONNECT ELECTRIC SERVICE (120/240V), AND REMOVE EXISTING LIGHTING CONTROL CABINET.
 ③ BARE GROUNDING CONDUCTOR IS INSTALLED SEPARATELY (OUTSIDE) DUCT.
 ④ CIRCUITS 3 & 4 ARE NOT TERMINATED IN POLE EB.

GENERAL NOTES:
 1. POLES FOR LIGHTING UNIT E1-E6 ARE WESTERN LIGHTING MA SERIES AND FOR LIGHTING UNIT EB IS STERNBERG 7700 SERIES.
 2. LIGHTING UNITS E1-E6 ARE CONNECTED AT 120V AND LIGHTING UNITS E7-E10 ARE CONNECTED AT 240V.

0 10' 20'

This drawing shall not be used nor reproduced either wholly or in part except when authorized by the engineer - Rempe-Sharpe

ACTION	NAME	No.	Date	Revisions	By
Design	G.S.				
Drawn	B.E.F.				
Checked	G.S.				

Powrtek Engineering, Inc.
 20900 SWENSON DR., SUITE 570
 WAUKESHA, WI 53886
 VOICE: 262.827-9875
 FAX: 262.827-9645

REMPE-SHARPE CONSULTING ENGINEERS
 IL P.D.F. LICENSE NO. 184-000895
 324 WEST STATE STREET - GENEVA, ILLINOIS 60134
 Telephone (630) 232-0827 - Fax (630) 232-1829

PROJECT
PEDESTRIAN UNDERPASS WINFIELD, ILLINOIS

SHEET TITLE
ELECTRICAL DEMOLITION PLAN

SCALE	PROJECT NO.	SHEET
1" = 20'	WF-451	No. E1
	DATE	Of E5
	DEC. 19, 2008	