

LIGHTING SCHEDULE

PAYITEM	LOCATION #1	LOCATION #2	LOCATION #3	LOCATION #4	LOCATION #5	LOCATION #6	PROJECT TOTAL
	2700 N INTERSECTION	S. MAIN ST. INTERSECTION	S. PUTNAM ST INTERSECTION	E. MAIN ST INTERSECTION	GORDON ST INTERSECTION	N. MOWEAQUA CONNECTOR	
ELECTRIC SERVICE INSTALLATION	1		1	1	1	1	5
CONDUIT PUSHED, 2" DIA., PVC	235	182	194	308	320	180	1419
CONDUIT PUSHED, 3" DIA., PVC			68				68
UNIT DUCT, 600V, 2-1C #10, 1/C #10 GROUND, (XLP-TYPE USE) 3/4" POLYETHYLENE	1403		1828	1411	1478	1434	7554
UNIT DUCT, 600V, 2-1C #4, 1/C #4 GROUND, (XLP-TYPE USE) 1" POLYETHYLENE		1156					1156
UNIT DUCT, 600V, 2-1C #6, 1/C #6 GROUND, (XLP-TYPE USE) 1" POLYETHYLENE		1316					1316
TRENCH AND BACKFILL FOR ELECTRICAL WORK	1064	2190	1458	993	1054	1150	7909
LUMINAIRE, SODIUM VAPOR, HORIZONTAL MOUNT, 250 WATT	8	8	8	8	8	8	48
LIGHTING CONTROLLER TYPE CB-RCS 60 AMP-240 VOLT			1				1
LIGHTING CONTROLLER PHOTOCELL RELAY	1			1	1	1	4
LIGHT POLE, ALUMINUM, 45 FT. M.H., 15 FT. DAVIT ARM	8	8	8	8	8	8	48
LIGHT POLE, FOUNDATION METAL, 15" BOLT CIRCLE, 8" X 6'	8	8	8	8	8	8	48
BREAKAWAY DEVICE, COUPLING, WITH STAINLESS STEEL SCREEN	32	32	32	32	32	32	192
REMOVAL OF EXISTING LIGHTING UNIT, SALVAGE	2	1	2	*	2	1	8

* TO BE REMOVED BY OTHERS