



NOTES:

1. SEE TRAFFIC SIGNAL PLANS FOR EXACT LOCATION.
2. THE AERIAL CABLE CLEARANCES SHOULD CONFORM TO NEC ARTICLE 225.18 (4) AND SHALL ALSO MEET CLEARANCE WITH RESPECT TO COMED STANDARDS.
3. NAPERVILLE ELECTRIC HIGH VOLTAGE TRANSMISSION LINES ARE RUNNING ON THE EAST SIDE OF IL ROUTE 59. THE REQUIRED VERTICAL AND HORIZONTAL CLEARANCES OF 20.5 FEET AND 19 FEET RESPECTIVELY SHALL BE FOLLOWED. THE CONTACT AT THE VILLAGE OF NAPERVILLE IN THE DEPARTMENT OF PUBLIC UTILITIES - ELECTRIC SHALL BE LARRY SLATE AT 630-420-6192.



USER NAME = jrt	DESIGNED - SJC	REVISED -
	DRAWN - NEM	REVISED -
PLOT SCALE = 100.0000' / in.	CHECKED - DNM	REVISED -
PLOT DATE = 1/30/2014	DATE - 1/30/2014	REVISED -

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

**TEMPORARY LIGHTING PLAN
US ROUTE 34 (OGDEN AVENUE) AT IL ROUTE 59**

SHEET NO. 1 OF 1 SHEET STA. TO STA.

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
311	2013-062TS	DUPAGE	49	40
CONTRACT NO. 60X34				
ILLINOIS FED. AID PROJECT				