


PARAPET CONDUIT DETAIL (ALLEN ROAD BRIDGE)



JUNCTION DETAIL (ROCK ISLAND TRAIL TUNNEL)

NOTES:

1. STAINLESS STEEL CONDUIT, COUPLINGS, AND ELBOWS SHALL BE ACCORDING TO SECTION 810 OF THE STANDARD SPECIFICATIONS, AS APPLICABLE, SHALL BE TYPE 304 OR TYPE 316, AND SHALL BE MANUFACTURED ACCORDING TO UL STANDARD 6A AND ANSI STANDARD C 80.1.
2. CONDUIT FITTINGS SHALL BE THE THREADED TYPE, SHALL BE TYPE 304 OR TYPE 316 STAINLESS STEEL, AND SHALL BE MANUFACTURED ACCORDING TO UL STANDARD 514B.

MAURER-STUTZ
ENGINEERS SURVEYORS

FILE NAME +	USER NAME + basvanson	DESIGNED -	REVISED -
S:\237\2013\23713009\001\AllenRoadPHD\CADD	CADD Sheets\0460603-shr-lighting 13.dgn	DRAWN -	REVISED -
Default	PLOT SCALE + 2.0000 1/16"	CHECKED -	REVISED -
	PLOT DATE + 1/29/2014 12:12:00 PM	DATE -	REVISED -

STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

ALLEN ROAD IMPROVEMENTS
LIGHTING - CONDUIT DETAILS

SCALE: SHEET 13 OF 19 SHEETS STA. TO STA.

F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
6584	105: (T2-THB)BY	PEORIA	487	281
6585			CONTRACT NO. 68683	
ILLINOIS FED. AID PROJECT				