**EXISTING LIGHTING UNIT TO REMAIN** NOTE: THE CONTRACTOR SHALL LOCATE, UNCOVER AND RE-REOUTE EXISTING LIGHTING UNIT TO BE RELOCATED EXISTING UNIT DUCT TO THE RELOCATED LIGHTING UNIT. THE COST RL RELOCATED LIGHTING UNIT OF THIS WORK SHALL BE INCLUDED IN THE RELOCATE EXISTING **EXISTING LIGHTING CONTROLLER** LIGHTING UNIT PAY ITEM. UNIT DUCT, 600V, 3-1C NO.6, 1/C NO. 6 GROUND, (XLP-TYPE USE), 1" DIA., POLYTHYLENE UNDERGROUND CONDUIT, COILABLE NONMETALLIC CONDUIT, 2.5" DIA., SCHEDULE 80 PROPOSED RELOCATED EXISTING LIGHTING UNIT STA 160+82, 83' LT. EXISTING LIGHTING UNIT TO BE RELOCATED PROPOSED RELOCATED EXISTING LIGHTING UNIT STA 167+69, 94' RT. EXISTING LIGHTING UNIT TO BE RELOCATED PROPOSED RELOCATED EXISTING LIGHTING UNIT EXISTING LIGHTING UNIT TO BE RELOCATED -STA 170+36, 82' RT COUNTY SHEETS NO.
SANGAMON 56 25
CONTRACT NO. 72F90 FILE NAME : DESIGNED -REVISED SECTION STATE OF ILLINOIS DRAWN REVISED LIGHTING RELOCATION PLANS (84-3)]-4 PLOT SCALE : 100,0000 1/ 10. CHECKED REVISED DEPARTMENT OF TRANSPORTATION

SHEETS STA.

PLOT DATE + Oct-17-2013 89:57:26AH

DATE

REVISED