


NOTES:

1. SEE DRAWING E-1 FOR ELECTRICAL SYMBOL LIST AND ABBREVIATIONS. SEE DRAWING E-2 FOR ELECTRICAL GENERAL NOTES.
 2. CONTRACTOR MUST ROUTE CONDUIT FROM A LOCATION SPECIFIED BY COMED TO THE PRIMARY SIDE OF THE PROPOSED SERVICE TRANSFORMER. CONDUIT MATERIAL AND SIZE TO BE DETERMINED BY COMED, AND PAID FOR UNDER THE "ELECTRIC UTILITY SERVICE CONNECTION" PAY ITEM. SEPARATE PAYMENT WILL NOT BE MADE.
 3. CONTRACTOR MUST REINSTALL EXISTING LIGHTING UNIT ON NEW POLE FOUNDATION WITH THE SAME BOLT CIRCLE DIAMETER AS WAS DETERMINED PER NOTE 3 ON DRAWING EL-6. SEE IDOT STANDARD DRAWING BE-301 FOR PROPOSED LIGHTING UNIT FOUNDATION DETAILS. FOUNDATION WILL BE PAID FOR UNDER THE "LIGHT POLE FOUNDATION, 24" DIAMETER" PAY ITEM. SEPARATE PAYMENT WILL NOT BE MADE.
 4. CONTRACTOR MUST CONFIRM THAT A 20A, 120V GFCI RECEPTACLE HAS BEEN INSTALLED AT 15'-0" ABOVE THE BASE OF EXISTING POLE TO BE RELOCATED. RECEPTACLES MUST BE INSTALLED WHERE ABSENT, AND CONNECTED TO RECEPTACLE PANEL WITHIN THE PROPOSED LIGHTING CONTROLLER "C103". SEE IDOT STANDARD BE-400 FOR PROPOSED RECEPTACLE REQUIREMENTS. THE COST OF ALL REQUIRED RECEPTACLES WILL BE INCLUDED IN THE "LIGHT POLE, ALUMINUM, 47.5 FT. M.H., 12 FT. MAST ARM" PAY ITEM. SEPARATE PAYMENT WILL NOT BE MADE.
 5. CONTRACTOR MUST CHANGE THE LIGHTING UNIT IDENTIFICATION ON THE REINSTALLED LIGHTING UNIT TO THE NEW NAME SHOWN ON THIS DRAWING.
 6. SEE DETAIL DRAWING FOR PROPOSED LIGHTING UNIT DETAILS. SEE IDOT STANDARD DRAWING BE-301 FOR PROPOSED LIGHTING UNIT FOUNDATION DETAILS.
- CONTRACTOR MUST RUN TEMPORARY AERIAL CABLE TO COMPLETE LIGHTING CIRCUITS A, B, G, AND H. 3-1/2" #2 & 1/2" #4 GROUND ELECTRIC CABLE ASSEMBLY SHALL BE USED FOR TEMPORARY UNDERGROUND AND VERTICAL RUNS ALONG WOOD POLES AS SHOWN ON DRAWING ED-8. THE COST OF THIS WORK SHALL BE INCLUDED IN THE "ELECTRIC CABLE ASSEMBLY IN TRENCH, 600V (EPR-TYPE TC) 3-1/2" NO. 2 AND NO. 4 GROUND" AND "AERIAL CABLE, 3-1/2" NO. 2 WITH MESSENGER WIRE" PAY ITEMS. SEPARATE PAYMENT WILL NOT BE MADE. RECEPTACLE CIRCUITS SHALL NOT BE ENERGIZED BY TEMPORARY MEANS.



100 S. WACKER DR.
 SUITE 500
 CHICAGO, IL 60606
 TEL (312) 935-1000
 FAX (312) 935-4198
URS

FILE NAME = D160M61-SHT-E22.dgn	USER NAME = michael_bartusiewicz	DESIGNED - MAE	REVISED -
		DRAWN - MAE	REVISED -
	PLOT SCALE = 100.000000' / in.	CHECKED - DAD	REVISED -
SHT_PLAN	PLOT DATE = 3/15/2013	DATE - 03/13/2013	REVISED -

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

151st STREET TEMPORARY ROADWAY LIGHTING PLAN - STAGE 1A

SCALE: 1"=50' SHEET 6 OF 7 SHEETS STA. 498+50.00 TO STA. 531+50.00

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
330	103R-4	COOK	877	433
E-22			CONTRACT NO. 60M61	
ILLINOIS FED. AID PROJECT				

D160M61-SHT-E22.dgn 3/15/2013 2:27:11 PM