



ITEM	QTY.	DESCRIPTION	MAT'L
1	1	CHECK VALVE SLEEVE	MUST BE SUPPLIED
2	1	MOUNTING CLAMP	MUST BE SUPPLIED

- NOTES:**
1. VALVE SHALL HAVE TWO TO THREE INCHES OF CRACKING PRESSURE
  2. VALVE IS TO BE INSTALLED WITH THE OUTLET VERTICAL
  3. PIPE INSIDE DIAMETER **MUST BE SUPPLIED**
  4. IT IS RECOMMENDED TO BOLT OR PIN TO PIPE AS SHOWN, 4 PLACES 90° APART

REVISIONS		ILLINOIS DEPARTMENT OF TRANSPORTATION
NAME	DATE	
		16" SERIES 37G CHECK VALVE DETAIL
SCALE: VERT. NONE HORIZ. NONE		DRAWN BY: FG
DATE 12/13/2005		CHECKED BY:

12/13/2005  
 c:\p\1631\163106\check\_valve.dwg  
 guffa\acm\p