



<u>BILL OF MATERIAL</u> FOR ONE HEADWALL

Wire Fabric	Sq Yd	65
Concrete Headwalls	Cu Yd	<i>10.</i> 5

Item	Unit	Quantity
Cast-In-Place Reinforced Concrete End Sections 72"	Each	1

NOTES

Class SI Concrete shall be used throughout.

Exposed edges shall be beveled 3/4".

Build tops of headwalls parallel to grade line.

For backfilling and embankment, See Standard Specifications.

When lapping sheets of welded wire fabric, the overlap measured between the outermost cross wires of each fabric shall not be less than 8".

Precast substitution not allowed.

HEADWALL DETAILS 72" Ø RCCP FAP RTE 315 STATION 1097+60 45° SKEW - RT FWD

HUTCHISON ENGINEERING, INC. JACKSONVILLE, ILLINOIS Date: January 31, 2006