



- LEGEND**
- LIGHT POLE, 35' M.H., 10' MAST ARM, AND LUMINAIRE, 200W, UNLESS OTHERWISE NOTED
 - UTILITY POLE MOUNTED MAST ARM, LUMINAIRE TO BE REMOVED BY OTHERS
 - EXISTING LIGHT POLE, SIZE AS NOTED
 - UD5C-10' UNIT DUCT WITH 4-1/2" NO. 4 AND 1/2" NO. 6 GROUND 600V (EPR-TYPE RHW) 1-1/2" POLYTHYLENE AND LENGTH AS NOTED
 - 4"-10' GALVANIZED STEEL CONDUIT, PUSHED, DIAMETER AND LENGTH AS NOTED
 - PROPOSED LIGHTING CONTROLLER, 120/240V, 100A
 - PROPOSED SERVICE CONNECTION
 - OFFSET FOUNDATION

- NOTES**
- ALL POLES SHALL BE OFFSET 8' FROM EDGE OF PAVEMENT TO CENTER OF POLE, UNLESS OTHERWISE NOTED.
 - EXISTING UTILITY POLE MOUNTED LUMINAIRES SHALL REMAIN IN USE DURING CONSTRUCTION.

E-3

PLOT DATE: DEC 22, 2005 11:51:00
 FILENAME: N:\PROJECTS\2005\Design\Lighting\3232-LIGHT-C3.dwg

Clorba Group, Inc. CONSULTING ENGINEERS 5507 North Cumberland Avenue, Suite 402 Chicago, Illinois 60666 Tel. 773.775.4009 Fax 773.775.4014 Email: chicago@clorba.com	
VILLAGE OF MOKENA LAPORTE ROAD REHABILITATION LAPORTE ROAD IMPROVEMENTS LIGHTING PLAN STATION 19+00 TO 24+25	
DESIGN: KDM	DATE: DEC. 2005
DRAWN: KDM	SCALE: 1"=20'
CHECKED: JMV	FILE NO.: 3232