



LEGEND

- HIGH MAST LIGHT TOWER.
- 400 W. HPS LUMINAIRE (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- HIGH MAST TOWER DESIGNATION.
- LIGHTED SIGN STRUCTURE WITH 170 W. FLUORESCENT LUMINAIRE, QUANTITY OF LUMINAIRE AS REQUIRED. (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- 3 POLE SAFETY SWITCH
- UNDERPASS LIGHTING UNIT, 70W HPS LUMINAIRE. (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- LIGHTING CONTROLLER
- GROUND FIELD
- ELECTRIC UTILITY SERVICE
- ELECTRIC CABLE ASSEMBLY
- CONVENTIONAL LIGHTING UNIT, 310 WATT HPS LUMINAIRE. (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)

LOAD TABLE
LIGHTING CONTROLLER "A"

CIRCUIT	RED PHASE		BLACK PHASE	
	AMPS	WATTS	CIRCUIT	WATTS
A	23.8	5,712	B	5,712
C	41.3	9,912	D	9,384
E	23.8	5,712	F	5,712
G	35.4	8,496	H	7,920
I	13.8	3,312	J	3,312
K			L	
M	16.3	3,912	N	3,696
O			P	
TOTAL	154.4	37,056	TOTAL	35,736

SINGLE LINE DIAGRAM
LIGHTING CONTROLLER "A"

NOTES:
1. SEE DRAWING ME-12 FOR WIRING DIAGRAM DETAILS

SINGH
SINGH & ASSOCIATES, INC.
CONSULTING ENGINEERS

300 W. ADAMS ST.
CHICAGO, IL 60606
TEL: (312) 629-0240
FAX: (312) 629-8448

REVISIONS	
NAME	DATE

SL07-01

ILLINOIS DEPARTMENT OF TRANSPORTATION
F.A.I. 90/94 (DAN RYAN EXPRESSWAY)
31st STREET TO I-57

SINGLE LINE DIAGRAM
LIGHTING CONTROLLER "A"
PROPOSED IMPROVEMENTS 2007

SCALE: NOT TO SCALE DRAWN BY: YJ
DATE: OCTOBER 29, 2004 CHECKED BY: TM

11/23/2004 2:37:36 PM