






**EXISTING LIGHTING CONTROLLER "T" LOAD TABLE**

CIRCUIT	RED PHASE		CIRCUIT	BLACK PHASE	
	AMPS	WATTS		AMPS	WATTS
A	14.0	3360	B	14.0	3360
C	21.0	5040	D	21.0	5040
E	21.0	5040	F	21.0	5040
G	--	--	H	--	--
I	--	--	J	--	--
K	--	--	L	--	--
M	--	--	N	--	--
O	--	--	P	--	--
Q	--	--	R	--	--
S	--	--	T	--	--
U	--	--	V	--	--
W	--	--	X	--	--
<b>TOTAL</b>	<b>56.0</b>	<b>13440</b>	<b>TOTAL</b>	<b>56.0</b>	<b>13440</b>

**NOTES:**

1. SEE DRAWING GE-1 FOR ELECTRICAL SYMBOL LIST AND ABBREVIATIONS.
2. CIRCUIT AND CABLE CALLOUTS ARE TYPICAL UNLESS NOTED OTHERWISE.

**LEGEND:**

-  EXISTING HIGH MAST LIGHT TOWER  
750W HPS LUMINAIRES (TYP.)  
(BLACK PHASE - SOLID SYMBOLS,  
RED PHASE - OPEN SYMBOLS)
-  HIGH MAST TOWER DESIGNATION
-  LIGHTING CONTROLLER
-  GROUND FIELD
-  EXISTING ELECTRIC UTILITY SERVICE DROP

LOAD TABULATION IS BASED ON THE FOLLOWING:  
750W HPS (HMT) LUMINAIRE: 3.5A AT 240V

