



## WIRING DETAIL

NO SCALE

### GENERAL NOTES

All taped splices shall use 2 layers of electrical tape over 3 layers of rubber tape as required by the Standard Specifications. Coat the finished taped splice with bonding compound.

All cable splices shall be taped unless another method has been specifically approved by the Engineer.

For example purposes the pole is shown on an anchor base. If the pole is required to be set on a breakaway base, consult the Standard Specifications.

All dimensions are in millimeters (inches) unless otherwise shown.

DATE	REVISIONS	POLE HANDHOLE WIRING
7/31/08	Updated	
		DRAFT

LGTO08A.DGN

FILE NAME = g:\zd40403\LI-21.dgn	USER NAME = kghan	DESIGNED - HS	REVISIONS -	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>POLE HANDHOLE WIRING</b>				F.A.J. RTE. 57	SECTION (46-2) I, HBR, VBR	COUNTY KANKAKEE	TOTAL SHEETS 558	SHEET NO. 268
PLOT SCALE = NONE	CHECKED - HS	DRAWN - KK	REVISIONS -		SCALE:	SHEET NO.	OF SHEETS	STA.	TO STA.	CONTRACT NO. 66409			
PLOT DATE = 12/17/2010	DATE - 12-17-2010	CHECKED - HS	REVISIONS -						FED. ROAD DIST. NO. 3 ILLINOIS FED. AID PROJECT				
		DATE - 12-17-2010	REVISIONS -										