

NOTES:


1. CONNECTIONS TO GROUND BUS BAR SHALL BE WITH 2-HOLE TONGUE LONG BARREL COMPRESSION LUGS BOLTED TO THE BUS BAR WITH 3/8" STAINLESS STEEL BOLTS, NUTS, & WASHERS.
2. GROUND BUS BAR SHALL BE MANUFACTURED IN THE UNITED STATES OF AMERICA TO COMPLY WITH THE AIRPORT IMPROVEMENT PROGRAM BUY AMERICAN REQUIREMENTS. GROUND RODS SHALL BE MANUFACTURED IN THE UNITED STATES OF AMERICA FROM 100% DOMESTIC STEEL. INCLUDE CERTIFICATION OF COMPLIANCE WITH SHOP DRAWING SUBMITTAL.

REVISION	DATE

EDGAR COUNTY AIRPORT
PARIS, ILLINOIS

IL PROJ.: PRG-4018
A.I.P. PROJ.: 3-17-0077-B13

Hanson Proj. No. 10A0053	File Name E-607.DWG	Scale NONE	Date 03/10/11
LAYOUT	CAT	RSS	MAM
DRAWN			
REVIEWED			



CONSTRUCT CROSSWIND
RUNWAY 18-36

VAULT GROUND BUS
RISER DIAGRAM