



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

May 8, 2009

SUBJECT: FAU Route 2706
Section BY-RS-2
Lake County
Contract No. 60G70
Item No. 183, May 15, 2009 Letting
Addendum A

NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

1. Revised pages i of the Table of Contents to the Special Provisions.
2. Revised page 10 of the Special Provisions.
3. Deleted pages 11 - 30 of the Special Provisions.

This Addendum deletes the Special Provision "HOT MIX ASPHALT PAY FOR PERFORMANCE USING PERCENT WITHIN LIMITS (D-1)".

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

Charles Ingersoll, Chief
Bureau of Design and Environment

A handwritten signature in black ink, appearing to read "Ted B. Walschleger" with a small "P.E." to the right.

By: Ted B. Walschleger, P. E.
Engineer of Project Management

cc: Diane O'Keefe, Region 1, District 1; Bill Frey, Estimates

TBW:MS:jc

TABLE OF CONTENTS

LOCATION OF IMPROVEMENT 1

DESCRIPTION OF IMPROVEMENT..... 1

MAINTENANCE OF ROADWAYS..... 2

RAILROAD PROTECTIVE LIABILITY INSURANCE (5 AND 10) (BDE)..... 2

STATUS OF UTILITIES TO BE ADJUSTED 3

RESTRICTION ON WORKING DAYS AFTER A COMPLETION DATE 3

COMPLETION DATE PLUS WORKING DAYS..... 3

CLEANING EXISTING DRAINAGE STRUCTURES 4

FRAMES AND LIDS TO BE ADJUSTED (SPECIAL)..... 4

TRAFFIC CONTROL PLAN..... 5

EPOXY COATING ON REINFORCEMENT (DISTRICT ONE) 5

FINE AGGREGATE FOR HOT- MIX ASPHALT (HMA) (D-1) 6

HOT MIX ASPHALT MIXTURE IL-4.75 (DISTRICT ONE) 6

HOT MIX ASPHALT – DENSITY TESTING OF LONGITUDINAL JOINTS (D-1) 9

TEMPERATURE CONTROL FOR CONCRETE PLACEMENT (DISTRICT ONE) 31

USE OF RAP (DIST 1)..... 31

TRAFFIC SIGNAL SPECIFICATIONS FOR DETECTOR REPLACEMENT AND/OR INSTALLATION ON ROADWAY GRINDING, RESURFACING, & PATCHING OPERATIONS 37

TEMPORARY INFORMATION SIGNING..... 40

GRADING AND SHAPING SHOULDERS..... 41

ALKALI-SILICA REACTION FOR CAST-IN-PLACE CONCRETE (BDE) 41

APPROVAL OF PROPOSED BORROW AREAS, USE AREAS, AND/OR WASTE AREAS INSIDE ILLINOIS STATE BORDERS (BDE) 44

CEMENT (BDE) 45

CONCRETE ADMIXTURES (BDE) 47

CONSTRUCTION AIR QUALITY - IDLING RESTRICTIONS (BDE)..... 50

DISADVANTAGED BUSINESS ENTERPRISE PARTICIPATION (BDE) 51

ENGINEER’S FIELD OFFICE TYPE A (BDE) 59

EQUIPMENT RENTAL RATES (BDE)..... 61

HOT-MIX ASPHALT - FIELD VOIDS IN THE MINERAL AGGREGATE (BDE) 62

HOT-MIX ASPHALT – PLANT TEST FREQUENCY (BDE) 63

HOT-MIX ASPHALT – TRANSPORTATION (BDE) 65

LIQUIDATED DAMAGES (BDE)..... 65

MULTILANE PAVEMENT PATCHING (BDE)..... 66

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM / EROSION AND SEDIMENT CONTROL DEFICIENCY DEDUCTION (BDE) 66

PAYMENTS TO SUBCONTRACTORS (BDE) 66

Definitions:

Density Test Location: The station location used for density testing.

Density Test Site: Individual test site where a single density value is determined.

Density Reading: A single, one minute nuclear density reading.

Density Value: The density determined at a given density test site from the average of two "density readings".

Quality Control / Quality Assurance (QC/QA)

1030.05(d) (3) add the following paragraphs:

Longitudinal joint density testing shall be performed at each random "density test location". Longitudinal joint testing shall be located at a distance equal to the lift thickness, or a minimum of two inches, from each pavement edge. For Example, on a four inch HMA lift the near edge of the nuclear gauge or core barrel shall be within four inches from the edge of pavement. The remaining 3 density test sites shall be equally spaced between the two edge readings. Documentation shall indicate whether the joint was confined or unconfined.

The joint density value shall be determined using either a correlated nuclear gauge or cores. When using a correlated nuclear gauge, two "density readings" shall be taken at the given density test site. The gauge shall be rotated 180 degrees between "density readings". If the two "density readings" are not within 1.5 lb/cu ft (23 kg/cu m) then one additional "density reading" shall be taken. Additional "density readings" taken at a given site shall not be allowed to replace the original "density readings" unless an error has occurred (i.e. the nuclear gauge was sitting on debris).

Pages 11 - 30 have been Deleted.
The next page is 31.

Revised 05/08/2009