



FABRICATED TOP OF BEAM ELEVATION TABLE

| Location | Beam No. 1 | Beam No. 2 | Beam No. 3 | Beam No. 4 | Beam No. 5 | Beam No. 6 |
|-----------------|------------|------------|------------|------------|------------|------------|
| ℄ Brg. S. Abut. | 445.87 | 445.96 | 446.03 | 446.07 | 445.91 | 445.74 |
| ℄ Pier No. 1 | 444.28 | 444.36 | 444.41 | 444.44 | 444.27 | 444.09 |
| ℄ Splice No. 1 | 444.07 | 444.15 | 444.19 | 444.22 | 444.05 | 443.87 |
| ℄ Splice No. 2 | 442.50 | 442.57 | 442.61 | 442.64 | 442.46 | 442.27 |
| ℄ Pier No. 2 | 442.25 | 442.32 | 442.36 | 442.38 | 442.20 | 442.01 |
| ℄ Brg. N. Abut. | 440.64 | 440.71 | 440.75 | 440.77 | 440.59 | 440.40 |

For fabrication use only.

FABRICATED TOP OF BEAM ELEVATION TABLE

| Location | Beam No. 7 | Beam No. 8 | Beam No. 9 | Beam No. 10 | Beam No. 11 | Beam No. 12 |
|-----------------|------------|------------|------------|-------------|-------------|-------------|
| ℄ Brg. S. Abut. | 445.51 | 445.58 | 445.63 | 445.48 | 445.31 | 445.11 |
| ℄ Pier No. 1 | 443.81 | 443.86 | 443.90 | 443.73 | 443.55 | 443.34 |
| ℄ Splice No. 1 | 443.58 | 443.63 | 443.66 | 443.50 | 443.32 | 443.10 |
| ℄ Splice No. 2 | 441.96 | 442.00 | 442.04 | 441.87 | 441.69 | 441.47 |
| ℄ Pier No. 2 | 441.70 | 441.75 | 441.78 | 441.61 | 441.43 | 441.21 |
| ℄ Brg. N. Abut. | 440.10 | 440.14 | 440.18 | 440.01 | 439.82 | 439.61 |

For fabrication use only.

NOTES:

- 1.) See Sheet B22 for Splice Details and Diaphragm Details.
- 2.) Load carrying components designated N.T.R. shall conform to the Impact Testing Requirements, Zone 2.
- 3.) All diaphragms shall be installed as steel is erected and secured with erection pins and bolts except as otherwise noted. Individual diaphragms at supports may be temporarily disconnected to install bearing anchor rods.