## STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION

## **GENERAL NOTES:**

- 1. All work on these sheets are to be performed in accordance with Articles 503, 540 and 543 of the Standard Specifications. See next sheet for the "Concrete End Sections" details.
- 2. This box culvert has no fill height. Precast concrete box culvert sections shall conform to the requirements of Article 540.06 of the Standard Specifications and the applicable requirements of AASHTO M273 (ASTM C 850), except that the aggregate shall conform to the requirements of Article 1003.02 of the Standard Specifications.
- 3. The Contractor shall determine whether culvert can be installed in two (2) or three (3) phases (Staging shown here is suggested only) and order sections' lengths as required. Joints to be sealed in accordance with Article 540.06 of the Standard Specifications.
- 4. For backfilling of embankment, see Article 207 thru 209 of the Standard Specifications.
- 5. Lifting holes shall be filled with concrete plugs and mastic, after box sections are in place.
- 6. Reinforcement and Concrete Quantities are provided for information only.

## TOTAL BILL OF MATERIAL

Pay Item	Unit	Total
Cast-in-Place Reinforced Concrete End Sections	Each	2
Precast Concrete Box Culvert, 6'X3'	Foot	23
Steel Railing, Type 2399	Foot	20
Removal and Disposal of Unsuitable Material for Structures	Cu. Yd.	5

## BILL OF MATERIAL

Bar	No	Size	Length	Shape
<i>b1</i>	4	No. 5	8'-0"	PARROLL
b2	2	No. 4	11'-0"	
ЬЗ	4	No. 4	14'-0"	
b4	4	No. 4	16′-8"	
b5	28	No. 4	5′-0"	
b6	4	No. 4	6'-3"	
d	24	No. 4	4'-3''	
Management of the second				
h 1	6	No. 5	21'-0"	
h2	8	No. 5	6′-6"	
300				
V	4	No. 5	7′-1"	
V1	4	No. 5	7'-1"	
V2	4	No. 5	6'-9"	
V3	4	No. 5	6'-6"	
V4	4	No. 5	6'-2"	
V5	4	No. 5	5′-11"	
V6	4	No. 5	5′-8"	44.444.444.44
V7	4	No. 5	5′-4"	
V8	4	No. 4	3'-1"	
L			1	

i i

1Ø:18:18 PM

DESIGNED VP

CHECKED CL

DRAWN VP

CHECKED SP

SINGH & ASSOCIATES, INC.
CONSULTING ENGINEERS

300 W. ADAMS ST.
CHICAGO, IL 60606
TEL: (312) 629-0240
FAX: (312) 629-8449

SHEET NO.