



GENERAL NOTES:

- 1.) Slope Steps will be required for all 12" minimum thickness "silver fills" and on fills with a height of 10 ft.
- 2.) The Step width shall be twice the Step depth but not less than 6 ft.
- 3.) Refer to Article 205.03 for Embankment to be constructed on Hillside or Slopes, or if existing Embankments are to be widened.
- 4.) Exact limits to be determined in the field.

SLOPE STEPS DETAIL

Typical Cross-Section Embankment Construction on Sidehill

**SLOPE STEPS DETAIL
DISTRICT CADD STANDARD
205001-D4
ELMORE ROAD BRIDGE
OVER FRENCH CREEK**

REPLACEMENT MATERIAL:



Standard Embankment
(In Accordance with 205 of
the Standard Specification)

DESIGNED	PJL
CHECKED	LLV
DRAWN	MGM
CHECKED	PJL

All dimensions are in inches unless otherwise noted.

AECOM
111 NE Jefferson Ave.
Peoria, Illinois 61602
Ph: 309.676.8464
Fax: 309.676.5445
IL Design Firm Reg.
No. 184-001518
www.aecom.com

HWY	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
R-15	08-00092-00-BR	PEORIA	32	26
STRUCTURE NO. 072-3147			STATION 7+27	
FED. ROAD DIST. NO. _		ILLINOIS	FED. AID PROJECT BROS-0143(049)	