

59TH STREET

ATEI

LAGRANGE ROAD
6+00

7+00

HH (E)

SEE ELECTRICAL ONE LINE DIAGRAM

PUSHED CONDUIT
2#6 AND 1#8 GRD - 1 1/4" C
(2 1/2" METAL TYPE BELOW ROADWAY)
NOTE 3

UNDER SEPARATE CONTRACT

NOTE 1
2#12 AND 1#12 GRD
3/4" C.
(TYP. FOR ALL QUADRANTS)

WP GFCI ABOVE GROUND

WP GFCI ABOVE GROUND

GENERAL PLAN NOTES:

1. STREETSCAPE LIGHTING CONTROL PANEL SHALL BE PAD MOUNTED ON CONCRETE BASE. SEE ELECTRICAL DRAWING 38.
2. ALL LIGHTING FIXTURES AND RECEPTACLES SHALL BE CONNECTED TO THEIR RESPECTIVES STREETSCAPE LIGHTING CONTROL PANELS. SEE ELECTRICAL DRAWING 38 FOR INSTALLATION DETAILS.
3. ALL PUSHED CONDUITS SHALL BE INSTALLED AT THE SAME TIME. SEE ELECTRICAL DRAWING 37 FOR CONDUITS TO BE INSTALLED FOR COMED UTILITY FEEDERS.

1 59TH STREET ELECTRICAL PLAN
1"=10'



TENG & ASSOCIATES, INC.
ENGINEERS/ARCHITECTS/PLANNERS
235 N. MICHIGAN AVE. CHICAGO, IL 60601
TELEPHONE: 312/616-0000

FILE NAME = \$FILEL\$	USER NAME = \$USER\$	DESIGNED -	REVISED - .2 11/3/2008
		DRAWN - IC	REVISED -
	PLOT SCALE = \$SCALE\$	CHECKED - PR	REVISED -
	PLOT DATE = 8/22/08	DATE - 4/30/09	REVISED -

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

59TH STREET ELECTRICAL PLAN

SCALE: AS NOTED STA. TO STA.

F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
	07-00035-00-LS	COOK	42	36
FED. ROAD DIST. NO. 1 ILLINOIS			CONTRACT NO. 63059	
FED. AID PROJECT				