


NOTES:

1. FOR GENERAL AND CONSTRUCTION NOTES
SEE SHEET 287.



N.T.S.

LEGEND

- PROPOSED ELECTRIC SERVICE INSTALLATION, 120V/240V, 60A
- PROPOSED LIGHTING CONTROLLER SINGLE DOOR, B-RCS, 60A, 120V/240V
- CIRCUIT DESIGNATION LUMINAIRE NUMBER
- PROPOSED UNDERPASS LUMINAIRE 70 WATT, HIGH PRESSURE SODIUM VAPOUR
- CONDUIT IN TRENCH, 1" DIA., PVC SCHEDULE 40, UNLESS OTHERWISE NOTED, WITH 3-1/8" NO. 10 AND 1-1/8" NO. 10 GROUND (EPR-TYPE RHW)
- CONDUIT EMBEDDED IN STRUCTURE 1" DIA., PVC, WITH 3-1/8" NO. 10 AND 1-1/8" NO. 10 GROUND (EPR-TYPE RHW)
- PROPOSED ELECTRICAL JUNCTION BOX, 4" x 4" x 3", EMBEDDED IN STRUCTURE

FILE NAME = #FILES*	USER NAME = #USER*	DESIGNED - XXX	REVISED -	KANE COUNTY DIVISION OF TRANSPORTATION	UNDERPASS LIGHTING PLAN DUNHAM ROAD / IL 25			F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
	PLOT SCALE = 20,000' / IN.	CHECKED - GHT	REVISED -					361	06-00214-15-BR	KANE/DUPAGE	545	272
PLOT DATE = 3/30/2009	DATE - 3/31/09	REVISED -		SCALE:	SHEET NO. OF SHEETS	STA.	TO STA.	CONTRACT NO. 63074				
								FED. ROAD DIST. NO. ILLINOIS FED. AID PROJECT				

x:\3900\3944\engineering_documents\Lighting\prp\in_ABC_Underpass_Dun_Lp_01.dgn