



**CIRCUIT BREAKER & ENCLOSURE LAYOUT**  
N.T.S.

- ELECTRICAL NOTES:**
1. CIRCUIT BREAKER ENCLOSURE SHALL BE LOCATED INSIDE WELL ENCLOSURE ON THE LONG SIDE WHICH IS AT THE HIGHEST ELEVATION RELATIVE TO EXISTING GRADE.
  2. CIRCUIT BREAKER ENCLOSURE SHALL BE STAINLESS STEEL NEMA 4X, SIZE 16"x12"x8" WITH PANEL AS SHOWN IN DETAIL.
  3. CIRCUIT BREAKER ENCLOSURE SHALL BE MOUNTED SO THAT THERE IS AT LEAST 1/4" AIR SPACE BETWEEN IT AND THE WALL.

FILE NAME = #FILEL#	USER NAME = #USER#	DESIGNED -	REVISED -	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>WELL ENCLOSURE ELECTRICAL DETAILS</b>				F.A.P. RTE. 788	SECTION 27T-7	COUNTY MADISON	TOTAL SHEETS 9	SHEET NO. 8
		DRAWN -	REVISED -						SCALE: SHEET NO. 8 OF SHEETS STA. TO STA.				CONTRACT NO. 76B51
		CHECKED -	REVISED -		FED. ROAD DIST. NO. ILLINOIS FED. AID PROJECT								
		DATE -	REVISED -										