

TRANSPORTATION BULLETIN



Illinois Department of Transportation

ADDENDUM NO. 2

Dated: June 10, 2008

For: Transportation Bulletin

Letting Date: June 13, 2008

Volume 11 No. 19r2

Dated: May 9, 2008 REV: June 4, 2008

Item No. 4A – Runway 9-27 lighting, NAVAIDS and signage; Runway
18-36 wind cones and signage

Rantoul National Aviation Center

Rantoul, Illinois

Champaign County

IL Project No.: TIP-3310

AIP Project No.: 3-17-0136-B9

Contract No.: RA012

REASON FOR ADDENDUM:

- Adjustment of plan quantities.
- Responses to questions from bidders.
- Clarification of contract drawings.

TO ALL PLAN HOLDERS:

REVISE CONTRACT DRAWINGS

DRAWING NO. G001, SUMMARY OF QUANTITIES

MODIFY:

Modify the following quantities in the Summary of Quantities:

SUMMARY OF QUANTITIES				
ITEM NO.	BID ITEM NO.	DESCRIPTION OF WORK	UNIT S	ESTIMATED QUANTITY
31	AR80305 6	GROUND ROD, 5/8" x 8'	EACH	133
32	AR80305 7	30/45W, 6.6A/6.6A ISOLATION TRANSFORMER	EACH	91
33	AR80305 8	100W, 6.6A/6.6A ISOLATION TRANSFORMER	EACH	8

DRAWING NO. E204, DETAIL 2 NOTES

ADD:

“4. THE VILLAGE OF RANTOUL WILL FURNISH AND INSTALL THE SERVICE PANEL AND PROVIDE POWER TO THE PRIMARY SIDE OF THE PANEL AT A COST OF \$7,500.00 PER LOCATION. THE CONTRACTOR SHALL INCLUDE THIS COST IN THE BID PRICE FOR PAY ITEM AR803059.”

REVISE PROPOSAL DOCUMENT

SCHEDULE OF PRICES

REPLACE:

The “Schedule of Prices” with the attached “Schedule of Prices,” which includes the following modifications:

The quantity of item number AR803056 is modified to be 133.

The quantity of item number AR803057 is modified to be 91.

The quantity of item number AR803058 is modified to be 8.

RESPONSES TO QUESTIONS FROM BIDDERS

QUESTION 1: The plans state that the 5KV cable in unit duct must be installed in trench, will plowing of the cable in unit duct be allowed?

ANSWER 1: The engineer will consider substitution of plowing for installation in trench after the contract is awarded if adequate project cost savings is demonstrated.

QUESTION 2: Is unit duct acceptable for pay items AR108086, AR108542 and AR110201?

ANSWER 2: The engineer will consider substitution of cable in unit duct installation for cable in 1" PVC after the contract is awarded if adequate project cost savings is demonstrated.

QUESTION 3: Is the counterpoise to be installed with the 5KV cable? If not, can the counterpoise be plowed in?

ANSWER 3: The counterpoise is not to be installed with the 5KV cable. The engineer will consider substitution of plowing for installation in trench after the contract is awarded.

QUESTION 4: Is the 2" concrete encased conduit connecting the master to the slave unit on the REILS incidental to the REILS or will it be paid under the AR110501 1-Way Conc. Encased Duct Pay Item?

ANSWER 4: This concrete encased conduit shall be incidental to the REILS.

QUESTION 5: Will boring of the 2" conduit connecting the master to the slave unit on the REILS under the pavement be allowed.

ANSWER 5: Yes, boring of the 2" conduit under the pavement will be allowed.

STATE JOB #- - - -

ILLINOIS DEPARTMENT OF TRANSPORTATION
 SCHEDULE OF PRICES
 CONTRACT NUMBER - RA012

ECMS081 DTGECM03 ECMR003 PAGE 1
 RUN DATE - 06/09/08
 RUN TIME - 134853

COUNTY NAME	CODE	DIST	AIRPORT NAME	FED PROJECT	ILL PROJECT
CHAMPAIGN	019	05	RANTOUL NATIONAL AVIATION CENT	3-17-0136-B9	TI-P -3310

ITEM NUMBER	PAY ITEM DESCRIPTION	UNIT OF MEASURE	QUANTITY	UNIT PRICE		TOTAL PRICE	
				DOLLARS	CENTS	DOLLARS	CTS
AR101920	BEACON REPLACEMENT	EACH	1.000 X			=	
AR107408	L-806 WIND CONE-8' LIGHTED	EACH	3.000 X			=	
AR108083	1/C #3 XLP-USE	L.F.	1,050.000 X			=	
AR108086	1/C #6 XLP-USE	L.F.	13,000.000 X			=	
AR108092	1/C #12 XLP-USE	L.F.	5,500.000 X			=	
AR108158	1/C #8 5 KV UG CABLE IN UD	L.F.	16,500.000 X			=	
AR108542	1/C #8 GROUND	L.F.	7,000.000 X			=	
AR108706	1/C #6 COUNTERPOISE	L.F.	15,000.000 X			=	
AR108756	1/C #6 GROUND	L.F.	300.000 X			=	
AR110012	2" DIRECTIONAL BORE	L.F.	500.000 X			=	
AR110014	4" DIRECTIONAL BORE	L.F.	850.000 X			=	
AR110201	1" PVC DUCT, DIRECT BURY	L.F.	6,500.000 X			=	
AR110217	1 1/2" STEEL DUCT, DIRECT BURY	L.F.	350.000 X			=	
AR110501	1-WAY CONC. ENCASED DUCT	L.F.	450.000 X			=	
AR110610	ELECTRICAL HANDHOLE	EACH	3.000 X			=	

RANTOUL NATIONAL AVIATION CENT
CHAMPAIGN

ILLINOIS DEPARTMENT OF TRANSPORTATION
SCHEDULE OF PRICES
CONTRACT NUMBER - RA012

ECMS081 DTGECM03 ECMR003 PAGE 2
RUN DATE - 06/09/08
RUN TIME - 134853

ITEM NUMBER	PAY ITEM DESCRIPTION	UNIT OF MEASURE	QUANTITY	UNIT PRICE		TOTAL PRICE	
				DOLLARS	CENTS	DOLLARS	CTS
AR125444	TAXI GUIDANCE SIGN, 4 CHARACTER	EACH	8.000 X		=		
AR125505	MIRL, STAKE MOUNTED	EACH	47.000 X		=		
AR125510	MIRL, BASE MOUNTED	EACH	1.000 X		=		
AR125545	MI THRESHOLD LIGHT BASE MTD	EACH	16.000 X		=		
AR125565	SPLICE CAN	EACH	63.000 X		=		
AR125610	REILS	PAIR	2.000 X		=		
AR125615	PAPI (L-880 SYSTEM)	EACH	2.000 X		=		
AR125901	REMOVE STAKE MOUNTED LIGHT	EACH	47.000 X		=		
AR125902	REMOVE BASE MOUNTED LIGHT	EACH	12.000 X		=		
AR125907	REMOVE REILS	PAIR	2.000 X		=		
AR150510	ENGINEER'S FIELD OFFICE	L.S.	1.000 X		=		
AR150520	MOBILIZATION	L.S.	1.000 X		=		
AR803053	SEGMENTED CIRCLE	EACH	1.000 X		=		
AR803054	REPLACE WINDSOCKS	EACH	2.000 X		=		
AR803055	1/2" PVC CONDUIT, IN SAWKERF	L.F.	2,500.000 X		=		

RANTOUL NATIONAL AVIATION CENT
CHAMPAIGN

ILLINOIS DEPARTMENT OF TRANSPORTATION
SCHEDULE OF PRICES
CONTRACT NUMBER - RA012

ECMS081 DTGECM03 ECMR003 PAGE 3
RUN DATE - 06/09/08
RUN TIME - 134853

ITEM NUMBER	PAY ITEM DESCRIPTION	UNIT OF MEASURE	QUANTITY	UNIT PRICE		TOTAL PRICE	
				DOLLARS	CENTS	DOLLARS	CTS
AR803056	GROUND ROD, 5/8" X 8'	EACH	133.000 X		=		
AR803057	30/45W, 6.6A/6.6A ISOLATION TRANS	EACH	91.000 X		=		
AR803058	100W, 6.6A/6.6A ISOLATION TRANSFO	EACH	8.000 X		=		
AR803059	120/240V, 1-PHASE, 100A ELECT. SE	L.S.	2.000 X		=		
AR901511	SEEDING-FORMULA 1	ACRE	2.000 X		=		
AR908510	MULCHING	ACRE	2.000 X		=		
				TOTAL		\$	

NOTE:

1. EACH PAY ITEM SHOULD HAVE A UNIT PRICE AND A TOTAL PRICE.
2. THE UNIT PRICE SHALL GOVERN IF NO TOTAL PRICE IS SHOWN OR IF THERE IS A DISCREPANCY BETWEEN THE PRODUCT OF THE UNIT PRICE MULTIPLIED BY THE QUANTITY.
3. IF A UNIT PRICE IS OMITTED, THE TOTAL PRICE WILL BE DIVIDED BY THE QUANTITY IN ORDER TO ESTABLISH A UNIT PRICE.
4. A BID MAY BE DECLARED UNACCEPTABLE IF NEITHER A UNIT PRICE NOR A TOTAL PRICE IS SHOWN.