



SCHEDULE OF QUANTITIES (SHEET 6)		
ITEM DESCRIPTION	UNIT	QTY.
REMOVE EXISTING CONCRETE FOUNDATION	EACH	1.0
UNDERGROUND CONDUIT, PVC, 90MM DIA.	METER	4.5
ELECTRIC CABLE IN CONDUIT, 600V (XLP-TYPE USE) 1/C NO. 2	METER	24.3
ELECTRIC CABLE IN CONDUIT, 600V (XLP-TYPE USE) 1/C NO. 4	METER	8.1
LIGHT TOWER FOUNDATION	METER	9.7
JUNCTION BOX (SPECIAL)	EACH	1.0
LIGHT TOWER, INSTALL ONLY	EACH	1.0

REVISED

FILE NAME * 88888 - High Mast Lighting Repair (Final)	USER NAME * kashbr 4-19-14) .dgn	DESIGNED - _____ DRAWN - _____	REVISED - _____ REVISED - _____	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	WIRING DIAGRAM I-74 & STERLING AVENUE	FBI/FAP RTE. 74/150	SECTION 72(7.9)1-4;8-1-6;10-1	COUNTY PEORIA-TAZEWELL	TOTAL SHEET SHEETS NO. 11 6	
	PLOT SCALE * 1/4" = 1' / 1/8" = 1'	CHECKED - _____	REVISED - _____			SCALE: _____	STA. _____ TO STA. _____	CONTRACT NO. 68888		
	PLOT DATE * 4/18/2014	DATE - _____	REVISED - _____			ILLINOIS FED. AID PROJECT				