



**WIRING DETAIL**

NO SCALE

**GENERAL NOTES**

All taped splices shall use 2 layers of electrical tape over 3 layers of rubber tape as required by the Standard Specifications. Coat the finished taped splice with bonding compound.

All cable splices shall be taped unless another method has been specifically approved by the Engineer.

For example purposes the pole is shown on an anchor base. If the pole is required to be set on a breakaway base, consult the Standard Specifications.

All dimensions are in millimeters (inches) unless otherwise shown.

FILE NAME =	USER NAME = dows00878	DESIGNED - RDN	REVISED -
I:\09Jobs\09L0027A\CADD\Elec\Sheet\07.dgn		DRAWN - ANC	REVISED -
PLOT SCALE = 40.0000' / 1in.		CHECKED - RDN	REVISED -
PLOT DATE = 04/02/2012		DATE - 02/02/12	REVISED -

**STATE OF ILLINOIS  
 DEPARTMENT OF TRANSPORTATION**

**NORTHMOOR ROAD STAGE 2 IMPROVEMENT  
 POLE HANDHOLE WIRING**

SCALE: NONE    SHEET NO. 8 OF 10 SHEETS    STA.    TO STA.

F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
6647	05-00302-01-PV	PEORIA	125	58
	11-00047-03-PV		CONTRACT NO. 89526	
FED. ROAD DIST. NO.	ILLINOIS FED. AID PROJECT		M-5093(137)	