



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

May 22, 2018

SUBJECT: FAU 7893 (Walnut Street)
Section 16-00063-00-RS (Taylorville)
Christian County
Contract No. 93716
Item 191
June 15, 2018 Letting
Addendum (A)

NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

1. Revised page 5 of the Special Provisions.

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bid.

Very truly yours,

Jack A. Elston, P.E.
Bureau Chief
Engineer of Design and Environment

A handwritten signature in cursive script, reading "Ted B. Walschleger P.E.".

By: Ted B. Walschleger, P.E.
Engineer of Project Management

the push on integral bell or by coupling using elastomeric sealing gaskets and meeting the requirements of F477. The nominal 10" restrained joint pipe fittings and accessories to conform to pressure rating 235 psi.

CATCH BASIN, MANHOLE, INLET, DRAINAGE STRUCTURE:

This work shall be done in accordance with Section 602 of the Standard Specifications and the following provisions:

This work shall consist of installing Type A inlets at locations shown in the construction plans and connect to the existing combined sewer through an existing gas trap. The proposed rim and invert elevations should closely match the existing rim and invert elevations shown on the demolition plan sheets. It is important to verify that the gas trap is functioning properly prior to backfilling. All proposed rim and invert elevations should be field verified and adjusted, if necessary, to provide a functioning drainage system.

This work shall include all labor, materials, fittings, adaptors, PVC storm sewers, and equipment to complete this item.

This work will be paid for at the contract unit price per each for INLETS, TYPE A, TYPE 3 FRAME AND GRATE.

Catch Basin, Type A, 5' Diameter Gas Trap:

This work shall be completed in accordance with the detail on sheet (11) eleven of the construction plans or in accordance with Standard Drawing 602001-02 as long as the outside storm sewer offset is greater than 12 inches.

This work shall include all labor, materials, fittings, adaptors, PVC storm sewer, Type 3 frame and grate, and equipment necessary to complete this item. This work shall be paid for at the contract unit price per each for CATCH BASINS, TYPE A, 5'- DIAMETER, TYPE 3 FRAME AND GRATE.

Manhole, Type A, 5' Diameter, Type 1 Frame, Closed Seal-Down Grate:

This work shall consist of field verifying elevations and location of an existing 12-inch combined sewer as shown on page 11 in the construction plans and construct a 5' diameter set-over manhole over the 12-inch combined sewer. A 10-inch gas-trapped storm sewer will connect into the manhole from the east and a 6-inch gas-trapped storm sewer from the west.

This work shall include all labor, materials, fittings, adaptors, PVC storm sewers, and Type 1 frame and closed, sealed grate.

This work shall be paid for at the contract unit price per each for MANHOLES, TYPE A, 5-DIAMETER, TYPE 1 FRAME, CLOSED LID.