

THE LOCATION, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ON THE PLANS IS NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.

CALL J.U.L.I.E. FOR UTILITY INFORMATION AT 1-800-892-0123. CONTACT AIRPORT PERSONNEL FOR ASSISTANCE IN LOCATING AIRPORT CABLES. CONTACT FAA FOR ASSISTANCE IN LOCATING FAA CABLES


**SUMMARY OF PROPOSED QUANTITIES (THIS SHEET)**

ITEM NUMBER	DESCRIPTION	UNIT	QUANTITY
AS107408	L-806 WIND CONE 8' LIGHTED	EA	2
AS108656	3/C #6 600V UG CABLE IN UD	L.F.	6,160
AS110014	4" DIRECTIONAL BORE	L.F.	335
AS800581	ELECTRICAL POWER FOR RWY 6 AND RWY 36 WIND CONES	L.S.	1

**WIND CONE NOTES**  
 THE PROPOSED WIND CONES SHALL BE INSTALLED AS SHOWN ON THIS SHEET & THE "WIND CONE ELEVATION DETAIL" SHEET, AND IN ACCORDANCE WITH THE SPECIAL PROVISIONS.

**LEGEND**

- EXISTING PAVEMENT
- PROPOSED DUCT
- PROPOSED 3/C #6 XLP-USE 600V UG CABLE IN UD - AR108656
- PROPOSED SUPPLEMENTAL WIND CONE
- EXISTING ELECTRICAL CABLES
- EXISTING WIND CONE



DATE	REVISION	BY

**DECATUR, ILLINOIS**
  
IL PROJ.: DEC-3588
  
IL PROJ.: 3-17-00

<small>HEL Project No. 802-08TXD_0800</small> <small>Elevation E-144.DWG</small> <small>Scale AS SHOWN</small> <small>Date 03/31/06</small>	<small>LAYOUT KNL 04/22/06</small> <small>DRAWN MV 04/25/06</small> <small>REVIEWED LDP 03/30/06</small>
------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------

Hanson Professional Services, Inc.  
1000 North State Street  
Springfield, IL 62703-2886  
Offices Nationwide

**TAXIWAY "C"**  
**RECONSTRUCTION**  
 ELECTRICAL SITE PLAN  
 RUNWAY 6 & RUNWAY 36  
 WIND CONES

APR 28, 2006 11:32 AM DWG  
 I:\AIRPORTS\DECATUR\802-08TXD\AIRPORT\SHEETS\E-144.DWG - 2006